From: Davies, Stella <stella.davies@wiltshire.gov.uk>
Sent: Wednesday, October 11, 2023 10:30 AM
To: Drainage <Drainage@wiltshire.gov.uk>; Tapscott, Steve <Steve.Tapscott@wiltshire.gov.uk>
Subject: RE: Land adjacent 70 Court Hill, Potterne, Devizes, SN10 5PN : Consultation - PL/2023/08174

Hi Steve,

Review of BGS mapping indicates that the site has good infiltration potential and recommends that soakaway testing is undertaken



It also suggest that groundwater is 5 m below surface but seasonal variations should be considered



Best wishes,

Stella Davies
Principal Drainage Engineer (Flood Risk)
Weather and Drainage/ Highways Asset Management and Commissioning
Wiltshire Council

Email: stella.davies@wiltshire.gov.uk
Web: www.wiltshire.gov.uk
Follow Wiltshire Council

Sign up to Wiltshire Council's email news service

