Wiltshire Council

Section 37 of the Electricity Act 1989

Application Reference Number: PL/2023/09257

Decision Date: 05 December 2023

Applicant:	Scottish and Southern Electricity Networks Faraday Road, Dorcan, Swindon, SN3 5EY
Particulars of Development:	SSEN have been requested to uprate the existing overhead line (OHL) from single to three-phase, along the route shown, as per the design document. In addition, we are also required to uprate the existing pole mounted transformer (PMT). This includes changing the existing single pole to a H pole construction and installing a larger capacity unit.
At:	Packhorse Lane, Purton, SN5 4LA

I am writing with regard to your letter for the above works received by the Council on the 25th of October 2023 The Council does not object to the proposed development, detailed above, being undertaken under the exemptions laid down in the Overhead Lines (Exemption) (England and Wales) Regulations 2009.

Parvis Khansari - Corporate Director, Place