

Existing Elevations




Front



Side



Rear




Side


Proposed Elevations




Front




Side




Rear




Side




Section A:A



Proposed
Loft Floor Plan



Existing
Ground Floor Plan



Existing
First Floor Plan

Brief specification

Existing roof construction

Interlocking clay tiles on 75x50mm rafter @ 400mm centre. Existing ceiling 12.5mm plasterboard. First floor ceiling height 2305mm, gable wall bath stone block & brick cavity arrangement.

Walls & flooring

100x50mm stud walls at 400mm centre bolted with 6inch timber locking bolt screws to form purlin. 12.5mm plasterboard & skim with counter batten to maintain air flow. 50x125mm rafters alongside existing from perimeter stud work to ridge. 105mm Actis Hybris insulation in-between rafter and stud walls with Actis H control throughout. 100x50mm gable walls & partition walls with 100mm fibreglass insulation.

Stairs

Staircase pitch 42° max, min going 220 & max riser 220mm. Tapered treads to measure 50mm at narrow end and 220 on the centre line. Headroom to be 2000mm min off pitch line & landing. Spindles 100mm max. Handrail to be 900mm min off the pitch line and landing line. Balustrades at 100mm apart.

Ventilation

Trickle vents to all windows min 800mm; ensure equivalent of continuous 25mm air gap at eaves level, 5mm continuous ridge ventilation is in place.

Electrics

All electrical work is required to meet the requirements of part P (electrical safety) to be designed, installed, inspected and tested by a competent person to do so. An appropriate BS 7671 electrical installation certificate to be issued for the work.

Fire regulations

Denotes mains operated, fully integrated smoke alarms with battery backup on all floors, & to be positioned 300mm from any lights, wall and avoiding location over treads. Provide fibreglass cavity barrier around any beams to maintain fill 1 hour fire resistance. Lighting to achieve of part L1B.

Drainage

32mm diameter PVC wastes to basin & showers. where waste runs exceed 1.7m use 50mm diameter. WC's are connected to existing SVP. Install mechanical extractor fan to shower room. SVP should terminate not less than 900mm above any opening within 3 meters.

Dormer Face & Cheeks

Vertical tiles hanging on tile battens & breathable roofing felt on BS 5747 on 9mm exterior OSB. 100x50mm studs at 400 centres with 105mm Actis Hybris and Actis H Control vapour barrier. 12.5mm plasterboard & skim.

Dormer roof

Resitrex or rubber single ply roofing on 19mm plywood decking on 50x50mm tapered firring strips falling 50-0mm. Dormer joists at 400 centres with 105mm Actis Hybris & Actis H Control.

Title: Loft conversion with rear flat roof dormer, Client: Mr & Mrs Stoppard, Address: 164D Bradford Road, Winsley,BA15 2HW, Date: Sept 2023, Scale: 1:100 & 1:50 A1, Local Authority: Wiltshire

Scale Bar 1:100

0 5 10

Scale Bar 1:50

0 1 2 3 4 5

SKD
Loft Conversion Specialists Ltd