

Wiltshire Council Planning Consultation Response

14th August 2024

Wiltshire Council Drainage Engineer
Technical Services Drainage Engineer
Wiltshire Council

Officer's Name: David Cox
Direct Line: 01225 716774

Application No: PL/2023/07503
Removal/variation of conditions
Variation of conditions 5, 6 and 7 of 15/11604/OUT - To become compliance conditions relating to the installed surface water drainage scheme and its associated maintenance regime.
Westbury and District Hospital, The Butts, Westbury, Wiltshire, BA13 3EL

Please note the particulars in connection with the above planning application are available to view on the planning website <http://www.wiltshire.gov.uk/planninganddevelopment.htm>

Documents Considered

- 0654 Westbury Hospital - Headwall relocation Technical Note - Rev B
- 0654-SK-301-B

On the 5th August 2024 the LLFA requested the following information before the application could be supported:

1. Flood exceedance routes are to be shown on the plan to prove that the topography will direct flows towards the bunded area.
2. Details on how the current basin will be filled (presumably using material from the proposed excavation?) are to be included in the technical note

The information supplied addresses these points and as such, the LLFA has no further objections to this application at this time.

We would request that as-built records are provided following construction, and that these are used where needed to update the hydraulic models.

--

James Playfair (AtkinsRéalis), working on behalf of Wiltshire Council Drainage.