

From: Mathew, Asher T (Distribution)

Sent: 18 July 2025 15:39

To: Madge, Adam <Adam.Madge@wiltshire.gov.uk>

Subject: Re: Proposed Ark Data Centre - planning application no PL/2024/05527 - Request for comments from SSEN Distribution

Hi Adam,

This customer has already secured capacity for the connection; however, there are both distribution and transmission dependency linked to the completion of several works. Please let me know if you need more information.

Thanks & Regards

Asher Mathew

System Planning Engineer

Scottish and Southern Electricity Networks

No. 1 Forbury Place, 43 Forbury Road, Reading
RG1 3JH



PRINCIPAL PARTNER SSE
**UN CLIMATE
CHANGE
CONFERENCE
UK 2021**
IN PARTNERSHIP WITH ITALY

From: Madge, Adam <Adam.Madge@wiltshire.gov.uk>

Sent: Friday, July 18, 2025 3:18 PM

To: Mathew, Asher T (Distribution)

Subject: [EXTERNAL] RE: Proposed Ark Data Centre - planning application no PL/2024/05527 - Request for comments from SSEN Distribution

This email was sent from outside SSE. Do not open any links or attachments unless you know the content is safe. If you are unsure, report it!

[Report Suspicious](#)

Asher

The applicants Ark have a Connection Agreement with SSE (reference EZH451-1)

Hope that's what you need to provide comment on the application.

Adam

Adam Madge
Principal Planning Officer

Development Management



Tel: 01722 434380

Email: adam.madge@wiltshire.gov.uk

Website: www.wiltshire.gov.uk

[Sign up](#) to Wiltshire Council's email news service

From: Mathew, Asher T (Distribution)

Sent: 18 July 2025 11:30

To: Madge, Adam <Adam.Madge@wiltshire.gov.uk>

Subject: Re: Proposed Ark Data Centre - planning application no PL/2024/05527 -
Request for comments from SSEN Distribution

Thanks Adam.

Thanks & Regards

Asher Mathew

System Planning Engineer

Scottish and Southern Electricity Networks

No. 1 Forbury Place, 43 Forbury Road, Reading
RG1 3JH



PRINCIPAL PARTNER SSE
**UN CLIMATE
CHANGE
CONFERENCE
UK 2021**
IN PARTNERSHIP WITH ITALY

From: Madge, Adam <Adam.Madge@wiltshire.gov.uk>

Sent: 18 July 2025 11:29 AM

To: Mathew, Asher T (Distribution)

Subject: [EXTERNAL] RE: Proposed Ark Data Centre - planning application no
PL/2024/05527 - Request for comments from SSEN Distribution

Mathew I have asked the agent for the application for that information. As soon as I have it I will pass it on to you. Adam Adam Madge Principal Planning Officer Development Management Tel: 01722 434380 Email: adam.madge@wiltshire.gov.uk Website:

Mathew

I have asked the agent for the application for that information. As soon as I have it I will pass it on to you.

Adam

Adam Madge
Principal Planning Officer

Development Management



Tel: 01722 434380

Email: adam.madge@wiltshire.gov.uk

Website: www.wiltshire.gov.uk

[Sign up](#) to Wiltshire Council's email news service

From: Mathew, Asher T (Distribution)

Sent: 18 July 2025 11:24

To: Madge, Adam <Adam.Madge@wiltshire.gov.uk>

Subject: Re: Proposed Ark Data Centre - planning application no PL/2024/05527 -
Request for comments from SSEN Distribution

Thank you, Adam, for sharing the details. Could you please confirm if this customer has an existing application with us, and provide the reference number of that application?

Thanks & Regards

Asher Mathew

System Planning Engineer

Scottish and Southern Electricity Networks

No. 1 Forbury Place, 43 Forbury Road, Reading
RG1 3JH



Scottish & Southern
Electricity Networks



PRINCIPAL PARTNER SSE
**UN CLIMATE
CHANGE
CONFERENCE
UK 2021**
IN PARTNERSHIP WITH ITALY

From: Madge, Adam <Adam.Madge@wiltshire.gov.uk>

Sent: 18 July 2025 10:47 AM

To: Mathew, Asher T (Distribution)

Subject: [EXTERNAL] RE: Proposed Ark Data Centre - planning application no PL/2024/05527 - Request for comments from SSEN Distribution

Hi Mathew It was good to speak to you about this yesterday and to understand Scottish and Southern's view on this matter. I said that I would get back to you on the power output of this Data Centre. The attached Breeam assessment states that

Hi Asher

It was good to speak to you about this yesterday and to understand Scottish and Southern's view on this matter. I said that I would get back to you on the power output of this Data Centre.

The attached Breeam assessment states that the data centre "is projected to hold 28 data halls (at 0.75MW each) for a total 21MW

IT load capacity." Is that the information you need in terms of what power the data centre will be using? Hopefully you can work out it out from those figures and what is available on the website.

Look forward to any comments you may have.

Adam

Adam Madge
Principal Planning Officer

Development Management



Tel: 01722 434380

Email: adam.madge@wiltshire.gov.uk

Website: www.wiltshire.gov.uk

[Sign up](#) to Wiltshire Council's email news service