



**Unit5, Anthony way
Edmonton
London
N18 3QT**

DATE September 8, 2025

Client:

**Murat Bozuglu
17-19 Tidworth road
Ludgershal
SP11 9DQ**

CONTRACTORS: Ventorn Ltd

Fitted equipment:

1. Carbon Filter box, 3 cells

This system will be fitted with each 3 carbon filter block units to remove any oil or grease, and smells that will come from the kitchen and restraint canopy that are created in the cooking process.

2. Helios Fan 560 – 1 phase
3. 1 x silencer on each fan Type: **R02-8-900** to be mount on either side of the fan to reduce the noise level.
4. 2 x ESP6000

Recommendations for maintenance of odor control system include:

- System employing fine filtration and carbon filtration. Change fine filters every two weeks.
- Change carbon filters every 4 to 6 months.
- Clean every 2-6 months

Considering the above advice, it is recommended that the following cleaning and maintenance schedule if observed based upon the described operations of the kitchen, which would be moderate use (6-12 hours a day).

Element Maintenance Task and Frequency:

Extract Duct	Clean 6 monthly
Fine Filters	Change every 2 weeks
Carbon filters	Change every 4 to 6 months

You will find all the specification about all the equipment that we have fitted to your premises on attached catalogue.

Best Regards
Farid Roodi