DW172 Coefficient Calculation

Customer:	KVS DORSET	**Date:**	09.10.25
Project:	LAMB - URCHFONT	**Ref No:**	KVSD-101
Canopy Ref:	Modify Existing Canopy - Size 4300x1400/1600x500/300		

Item Ref:	Appliance:	Length (mm)	Width (mm)	Power Source	Area (m^2)	Coeffieicnt Factor	Flow Rate (m^3/s)
	Stand-Mounted 10 grid Combination Oven	750.00	783.00	Electric	0.59	0.32	0.19
	Benches, Spreaders & Worktops	300.00	800.00	NA	0.24	0.03	0.01
	Deep Fat Fryer (1 or 2 no.)	600.00	632.00	Electric	0.38	0.45	0.17
	Benches, Spreaders & Worktops	300.00	800.00	NA	0.24	0.03	0.01
	Chargrill / Charbroiler	600.00	652.00	Gas	0.39	0.95	0.37
	Benches, Spreaders & Worktops	300.00	800.00	NA	0.24	0.03	0.01
	Open-Top Range & Oven (1 or 2 no.)	900.00	770.00	Gas	0.69	0.40	0.28
	Benches, Spreaders & Worktops	300.00	800.00	NA	0.24	0.03	0.01
		0.00	0.00		0.00		0.00