

Further to your email below, please find attached the requested outstanding information and the following response to the points raised in the 1st PDF attachment you issued:-

- *Request for Cross sections* - hereby attached - Drainage Details drawing ref. 115154-CAL-XX-XX-DR-D-0053-(A)-Drainage Details 4-4 (Acknowledged this was missing in the previous submission).
- *Request for a manhole / inspection schedule* - hereby attached a copy of the surface and foul water manhole schedules drawings ref. 115154-CAL-XX-XX-DR-D-0090-(A)-Proposed Surface Water Manhole Schedule and 115154-CAL-XX-XX-DR-D-0091-(A)-Proposed Foul Water Manhole Schedule.
- *Request for confirmation and acceptance of an agreed connection point* - The project is in the detailed design stage, and the consents for the proposed sewer connections will be obtained with Wessex Water under the S106 agreement.
- *Query raised - 5. Although a CCTV survey has been undertaken, it is not clear if the line from SWMH-06 to the public SW line in the road has been undertaken. Please can a plan be supplied that compliments the CCTV report which clearly ties in the Section References to their extent* - This specific public SW line is referred as “line 4” under Section 5 of the CCTV survey report. The extracts of the CCTV survey report, Section 5 and markup plan are enclosed.