

Highway Development Management Consultation Response

Planning Application Ref: PL/2025/08009

Site Address: Prospect West, Bumpers Way, Bumpers Farm Industrial Estate, Chippenham.

Proposal: Retrospective planning permission for a temporary generator connected to Vectura House to be made a permanent fixture. No car parking spaces have been used for the compound as it was originally a gas cylinder storage area which was unused. The generator is a Kohler VC350C2 with acoustic protection of 81 dB(A) at 1m, 71 dB(A) at 7m and 65 dB(A) at 15m.

Date of Consultation Response: 01/12/2025

I refer to the above planning application dated 03/11/2025 seeking retrospective planning permission for a temporary generator connected to Vectura House to be made a permanent fixture. No car parking spaces have been used for the compound as it was originally a gas cylinder storage area which was unused. The generator is a Kohler VC350C2 with acoustic protection of 81 dB(A) at 1m, 71 dB(A) at 7m and 65 dB(A) at 15m.

On site vehicle parking was previously lost through an earlier application in this location without prior consultation with highways, the proposals would not result in any further loss to vehicle parking provision and therefore it is considered that no objection be raised with regard to highways.

If you have any queries regarding the above advice, please contact:

HighwaysDevelopment@Wiltshire.gov.uk