

Charles Vernon - Chalcourt, Dark Lane, Malmesbury, SN16 0BB

MCS 020(a) - Heat Pump Sound Calculator

Assessment Details

Heat pump model is Cosy6 and it is 25.0 metres from the assessment window.

There are 2 reflecting surfaces including the floor and it is not seen.

The assessment position is one metre perpendicular to the centre of the closest habitable room.

Step	Instructions	MCS contractor results/notes
1	Assessment Date	03/12/2025
2	Assessment Position	Ground floor window of the 'The Pines' when viewed looking east of site
3	A-weighted sound power level of the heat pump dBA	58.0
4a	Determine the directivity 'Q' of the heat pump noise.	Q4
4b	Measure the distance from the heat pump to the assessment position in metres	25.0
5	Determination of barrier correction - select barrier type	No barrier
6	Determination of barrier correction - select line of sight	Not seen
7	Calculate Sound Pressure Level	25.1
8	Final Result?	Pass

Final Sound Pressure Level: 25.1 dB(A) - COMPLIANT

This assessment follows the MCS 020 planning standard for heat pumps.
Maximum permitted sound level at assessment position: 37 dB(A)

Annotated Planning Application Photo

