

From: Annelisa Nicholas

Sent: Tuesday, December 16, 2025 19:49

To: Parker-Miles, Selina <Nina.Parker-Miles@wiltshire.gov.uk>

Subject: Re: 34 Lower Stoke, Limpley Stoke, Bath, BA2 7FR : PL/2025/09467

Hi Selina,

Apologies, I forgot to annotate that.

The retaining wall will have a French drain at the base which will connect to the soakaway in the car park area. Please see the updated drawing attached.

Thanks,

Anna