



KR07816

Tesco Express Ludgershall

Noise Impact Assessment...

Standard: British Standard 4142: 2014

Site: Tesco Express Ludgershall

Address: 41 Andover Road

Ludgershall

Wiltshire

Postcode: SP11 9LU

Customer: Tesco Stores Ltd

Address: Shire Park

Kestrel Way

Welwyn Garden City

Hertfordshire

Postcode: AL7 1GA

Issue: Version 1.1

Date: 23rd September 2025

Status: Current Document

KR Associates (UK) Ltd

Quietly confident...

Revisions...

KR07816		Project	Tesco Express Ludgershall		
		Title	Noise Impact Assessment - Proposed Replacement Plant		
		Standard	British Standard 4142: 2014 + A1: 2019		
Issue	Date	Details of Revision			
v1_1	03/09/25	Description	Report issue for submission to Local Authority		
		Signature			
		Name	Mr. R. Scrivener	Miss N Truman	Mr R Scrivener
		Position	Technical Director	Project Manager	Technical Director

Disclaimer...

This report is strictly confidential and is designed to meet the requirements of the customer. It is not intended for and should not be relied upon by any third party and no responsibility is undertaken to any third party. No Liability is accepted outside the scope of this report in strict accordance with the standard terms and conditions.

KR Associates...

KR Associates (UK) Ltd (Company No. 04813349) registered office at 56 Bassett Green Road, Southampton. SO16 3DX.

Table of Contents....

1. Executive Summary.....	5
1.1. Instruction	5
1.2. Executive Summary (Repeated at Section 6).....	5
1.2.1 Assessment Position	5
1.2.2 Background Noise Measurements	5
1.2.3 Criterion at Assessment Position	5
1.2.4 Mitigation Measures	5
1.2.5 Assessment of Noise Levels	5
1.2.6 Conclusions	5
2. Site Location.....	6
2.1. General Location of Site	6
2.2. Sound Power Levels of Source	7
3. Background Noise Levels.....	8
3.1. Weather During Survey	8
3.1.1 Wind Speed, Gust and Direction	8
3.1.2 Rainfall, Temperature and Dew Point	8
3.1.3 Impact of Weather	8
3.2. 24-hour Background Measurements	9
3.3. Modal Analysis of Background Data	9
4. Criterion.....	10
4.1. National Planning Policy Framework 2024	10
4.1.1 Scope of Standard	10
4.1.2 Conserving and Enhancing the Natural Environment	10
4.1.3 Appropriate Development	10
4.2. Noise Policy Statement for England: 2010	11
4.2.1 Scope of Standard	11
4.2.2 Criterion	11
4.3. Night Noise Guidelines (“NNG”)	11
4.3.1 Recommendation for Health Protection	11
4.3.2 Description of Effect of Change in Noise Level	11
4.4. British Standard 4142: 2014 + A1: 2019	12
4.4.1 Testing Standard	12
4.4.2 Criterion	12
4.4.3 Feature Correction	12
4.5. Local Authority Requirements	13
4.5.1 Local Plan	13
4.5.2 Proposed Criterion	13
5. Calculations of Noise Levels.....	14

5.1. ISO 9613 – Part 2:1996	14
5.1.1 Source Directivity (D_c)	14
5.1.2 Geometric Divergence (A_{div})	14
5.1.3 Ground Absorption (A_{gr})	14
5.1.4 Atmospheric Absorption (A_{atm})	14
5.1.5 Barrier Effect (A_{bar})	15
5.2. Calculation of Plant Noise Levels	15
5.2.1 Day Time (07:00 to 23:00)	15
5.2.2 Night Time (23:00 to 07:00)	15
5.3. Assessment of Average Noise Levels (BS 4142: 2014 + A1: 2019)	16
6. Conclusions	17
6.1. Assessment Position	17
6.2. Background Noise Measurements	17
6.3. Criterion at Assessment Position	17
6.4. Mitigation Measures	17
6.5. Assessment of Noise Levels	17
6.6. Conclusions	17
6.7. Uncertainty	17
7. Appendix A - BS 4142:2014 + A1: 2019 Information to Be Reported... ..	18
7.1. a) Competency	18
7.2. b) Source Under Investigation	18
7.3. c) Subjective Impression of Source at Assessment Position	18
7.4. d) Existing Contexts	19
7.5. e) Relative Positions	19
7.6. f) Noise Measurement Equipment Calibration	20
7.7. g) Noise Measurement Equipment Operation Test	20
7.8. h) Weather Conditions	20
7.9. i) Date of Measurements	20
7.10. j) Measurement Time Interval	21
7.11. k) Reference Time Interval	21
7.12. l) Specific Noise / m) Background Noise / n) Rating / o) Assessment / p) Conclusions	21

1. Executive Summary....

1.1. Instruction

KR Associates (UK) Ltd have been instructed by Tesco Stores Ltd to undertake an environmental noise survey at the Tesco Express located at 41 Andover Road, Ludgershall. The report will determine if the installation of the replacement plant will have a significant adverse impact in terms of noise on the local noise sensitive properties.

1.2. Executive Summary (Repeated at Section 6)

1.2.1 Assessment Position

The 1st floor bedroom at the rear of 43 Andover Road is located between 5 m and 6 m from the dedicated plant area at the side of store where it is proposed to locate the replacement remote gas cooler and two new AC heat pumps.

1.2.2 Background Noise Measurements

Day Time (07:00 – 19:00)			Evening (19:00 – 23:00)			Night Time (23:00 – 07:00)		
L _{Amax,1h}	L _{Aeq,1h}	L _{A90,1h}	L _{Amax,1h}	L _{Aeq,1h}	L _{A90,1h}	L _{Amax,15m}	L _{Aeq,15m}	L _{A90,15m}
58 - 75 dB	50 - 57 dB	44 - 50 dB	53 - 77 dB	43 - 55 dB	39 - 46 dB	41 - 68 dB	38 - 53 dB	26 - 49 dB
Minimum Background		44 dB	Minimum Background		39 dB	Modal Background		30 dB

1.2.3 Criterion at Assessment Position

To comply with the revised version of the National Planning Policy Framework (“NPPF”) and the guidance within the Local Plan, the resultant noise levels at the nearest residential dwellings are below the minimum background noise levels when assessed in accordance with British Standard 4142: 2014 + A1: 2019.

1.2.4 Mitigation Measures

The background noise levels are very low at this site and the residential dwellings are very close. Therefore, it will be necessary to install the compressor pack and two AC units within acoustic housings. The assessment has assumed the units are installed within acoustic housings.

1.2.5 Assessment of Noise Levels


Day Time (07:00 – 19:00)			Evening (19:00 – 23:00)			Night Time (23:00 – 07:00)		
L _{Aeq,1h}	L _{A90,1h}	BS4142	L _{Aeq,1h}	L _{A90,1h}	BS4142	L _{Aeq,1h}	L _{A90,1h}	BS4142
33 dB	44 dB	-11 dB	33 dB	39 dB	-6 dB	27 dB	30 dB	-3 dB

1.2.6 Conclusions

The resultant noise levels from the proposed mechanical equipment will result in noise levels that comply in full with the Local Plan and are at levels that are very unlikely to give rise to complaints from residents.

2. Site Location...

2.1. General Location of Site



The Tesco Express is located on Andover Road with a small car park at the front of the store. Planning permission has been granted for new residential dwellings at the rear of the site on the former garage / workshop. The 1st floor bedroom window at the rear of 43 Andover Road is located around 6m from the replacement gas cooler and the two AC units repositioned on the flat roof at the side of the store.

2.2. Sound Power Levels of Source


The following table shows the sound power level of the proposed low noise gas cooler, the Carrier compressor pack installed within the Environ EcoM Sonus Enclosures and the two Daikin RZAG AC heat pumps installed within individual acoustic enclosures.

Source	Description of Source	Distance to Residential 1 st floor No 43	Manufacturers Sound Power Levels		
			07:00 – 19:00	19:00 – 23:00	23:00 – 07:00
Source 1	Low Noise Gas Cooler 2.71m x 1.21m x 1.60m high <i>24 dB(A) at 10m</i>	5.5m	L _{w(A)} 56 dB		
Source 2	Carrier Compressor Pack (Enclosed) 1.50m x 1.20m x 2.40m high <i>20 dB(A) at 10m</i>	6.1m	L _{w(A)} 52 dB	Not Operating	
Source 2	Daikin RZAG 125 NV1 AC Unit (Enclosed) 1.75m x 1.10m x 1.66m high <i>23 dB(A) at 10m</i>	7.5m	L _{w(A)} 55 dB		
Source 3	Daikin RZAG 125 NV1 AC Unit (Enclosed) 1,75m x deep x 1.66m high <i>23 dB(A) at 10m</i>	8.6m	L _{w(A)} 55 dB		


3. Background Noise Levels...

3.1. Weather During Survey

3.1.1 Wind Speed, Gust and Direction




3.1.2 Rainfall, Temperature and Dew Point




3.1.3 Impact of Weather

An analysis of the background data recorded on site indicates that the prevailing weather did not adversely impact the results.

3.2. 24-hour Background Measurements



3.3. Modal Analysis of Background Data



4. Criterion...

4.1. National Planning Policy Framework 2024

4.1.1 Scope of Standard

The revised National Planning Policy Framework published in December 2024 provides an assumption in favour of sustainable development that meets the three overarching objectives: economic, social, and environmental. Paragraph 11 provides guidance for decision makers:

"For decision-taking this means:...

c) approving development proposals that accord with an up-to-date development plan without delay; or

d) ...granting permission unless...

i) the application of policies in this Framework... provides a strong reason for refusing the development proposed; or

ii) any adverse impacts of doing so would significantly and demonstrably outweigh the benefits...."

4.1.2 Conserving and Enhancing the Natural Environment

Paragraph 187 of the NPPF provides the following guidance on noise:

"Planning policies and decisions should contribute to and enhance the natural and local environment by:

e) preventing new and existing development from contributing to, being put at unacceptable risk from, or being adversely affected by, unacceptable levels of ...noise pollution..."

4.1.3 Appropriate Development

Paragraph 198 of the NPPF requires the development to be appropriate for its location:

"Planning... decisions should also ensure that new development is appropriate for its location...

a) mitigate and reduce to a minimum potential adverse impacts resulting from noise from new development - and avoid noise giving rise to significant adverse impacts on health and the quality of life⁷².

b) identify and protect tranquil areas which have remained relatively undisturbed by noise and are prized for their recreational and amenity value...

⁷²*See Explanatory Note to the Noise Policy Statement for England (Department for Environment, Food & Rural Affairs, 2010)"*

4.2. Noise Policy Statement for England: 2010

4.2.1 Scope of Standard

The Noise Policy Statement for England published in 2010 defines three aims:

*“**Avoid** significant adverse impact on health and the quality of life.*

***Mitigate** and minimise adverse impacts on health and quality of life; and*

***Contribute** to the improvement of health and the quality of life.”*

4.2.2 Criterion

The NPSE defines significant adverse and adverse impact in terms of noise:

*“**LOAEL** – Lowest Observed Adverse Effect Level*

This is the level above which adverse effects on health and quality of life can be detected.

***SOAEL** – Significant Observed Adverse Effect Level*

This is the level above which significant adverse effects on health and quality of life occur.”

4.3. Night Noise Guidelines (“NNG”)

The European Union and the World Health Organisation published the document *“Night Noise Guidelines for Europe”* in 2009.

4.3.1 Recommendation for Health Protection

“Below the level of 30 dB $L_{night, outside}$ no effects on sleep are observed except for a slight increase in the frequency of body movements during sleep due to night noise.

... 40 dB $L_{night, outside}$ is equivalent to the lowest observed adverse effect level (LOAEL) for night noise.

Above 55 dB the cardiovascular effects become the major public health concern.”

For reference the $L_{night, outside}$ is the average outside noise level calculated over an 8-hour period (EU: 2002/49/EC).

4.3.2 Description of Effect of Change in Noise Level

Noise Level Change (dB)	Subjective Response	Significance
0.1 – 2.9	Barely perceptible	Minor Impact
3.0 – 5.9	Noticeable	Moderate Impact
6.0 – 9.9	Up to a doubling of loudness	Substantial Impact
10.0 or more	More than a doubling of loudness	Major Impact

4.4. British Standard 4142: 2014 + A1: 2019

4.4.1 Testing Standard...

British Standard 4142: 2014 + A1: 2019 provides a method for assessing the likely effects of sound from industrial or commercial nature on *“people who might be inside or outside a dwelling used for residential purposes.”*

4.4.2 Criterion

The standard provides 3-levels of impact based on the calculated Rating Levels:

“A difference of around +10 dB or more is likely to be an indication of a significant adverse impact, depending on the context.

A difference of around +5dB is likely to be an indication of an adverse impact, depending on the context.

Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact, depending on the context.”

4.4.3 Feature Correction

It is appropriate to add a character correction where there is a new source that cannot be measured in line with British Standard 4142: 2014 + A1: 2019. The 3 methods for approaching this are the subjective, objective, and reference methods. In this report the subjective method is used.

Section 9.2 Subjective Method	Perceptibility to noise sensitive façades	Correction
Tonality Ranging from not tonal to prominently tonal	Not tonal	+0
	Just perceptible	+2
	Clearly perceptible	+4
	Highly perceptible	+6
Impulsivity Considering both the rapidity and any overall change in sound levels	Not impulsive	+0
	Just impulsive	+3
	Clearly impulsive	+6
	Highly impulsive	+9
Readily Distinctive Characteristic is neither tonal nor impulsive	Is not present	+0
	Is present	+3
Intermittency Identifiable “on/off” conditions	Is not present	+0
	Is present	+3

4.5. Local Authority Requirements

4.5.1 Local Plan

The Wiltshire Council Core Strategy was fully adopted in January 2015 including Policy 57 entitled *“Ensuring high quality design and place shaping.”*

“A high standard of design is required in all new developments, including extensions, alterations, and changes of use of existing buildings. Development is expected to create a strong sense of place through drawing on the local context and being complementary to the locality. Applications for new development must be accompanied by appropriate information to demonstrate how the proposal will make a positive contribution to the character of Wiltshire through:

- vii. having regard to the compatibility of adjoining buildings and uses, the impact on the amenities of existing occupants, and ensuring that appropriate levels of amenity are achievable within the development itself, including the consideration of privacy, overshadowing, vibration, and pollution (e.g. light intrusion, noise, smoke, fumes, effluent, waste or litter).”*

4.5.2 Proposed Criterion

It would be recommended that the proposed noise emissions are below the minimum 15-minute background noise level at the nearest noise sensitive property.

5. Calculations of Noise Levels...

5.1. ISO 9613 – Part 2:1996

The International Standards Organisation (“ISO”) published ISO 9613 – Part 2: 1996 entitled “*Acoustics – Attenuation of sound during propagation outdoors – Part 2: General method of calculations*” details the corrections that are required to establish the resultant noise levels of the existing and proposed plant at the assessment position.

5.1.1 Source Directivity (D_c)

A correction is made to account for the location of the source and the effect of additional reflective surfaces excluding the ground and is contained within section 6 of ISO 9613 - Part 2: 1996.

Number of Surfaces	Correction in dB (D_c)
1 Reflective Surface	+3 dB
2 Reflective Surfaces	+6 dB
3 Reflective Surfaces	+9 dB

5.1.2 Geometric Divergence (A_{div})

A correction is made for the distance between the source and assessment position using the following formula defined in section 7.1 of ISO 9613-Part 2: 1996.

Formula	Symbols
$A_{div} = 20 \cdot \log_{10} (d/d_0) + 11$	A_{div} = Reduction due to Geometric Divergence (dB) d = Distance from source to receiver (m) d_0 = reference distance (1m)

5.1.3 Ground Absorption (A_{gr})

A correction is made for the effect of the ground between the source and receiver depending on whether it is considered hard or soft ground.

Type of ground	Correction in dB (A_{gr})
Hard Ground	+ 3 dB
Soft Ground	+ 0 dB

5.1.4 Atmospheric Absorption (A_{atm})

As the source was less than 100m from the receiver position (assessment position) no correction was made for atmospheric absorption.

5.1.5 Barrier Effect (A_{bar})

A correction is made for any barrier in the direct line of sight between the source and the assessment position and is detailed in section 7.4 of ISO 9613-Part 2: 1996. For clarity, the K_{met} meteorological correction has been ignored and C_2 equals 40 and C_3 equals 1.

Formula	Symbols
$A_{bar} = 10 \cdot \log_{10} [3 + (40 \cdot \delta / \lambda) - A_g]$ *Note 1 where $\delta = a + b - r$ and $\lambda = c / f$	A_{bar} = Effective barrier attenuation (dB) A_g = Total Ground Absorption (dB) *Note 1: Only apply the A_g correction if $A_g > 0$ δ = Path difference (m) a = Distance from source to barrier head (m) b = Distance from barrier head to assessment position (m) r = Distance from source to assessment position (m) λ = Wavelength of sound (m) c = Speed of sound – Assumed to be 342 ms ⁻¹ f = Octave band centre frequency (Hz)

5.2. Calculation of Plant Noise Levels

5.2.1 Day Time (07:00 to 23:00)

Day Time (07:00 to 23:00)		Source	ISO 9613 – Part 2: 1996 Corrections					Assessment
Ref	Description	L_w	D_c	A_{div}	A_{gr}	A_{atm}	A_{bar}	L_p
1	Low Noise Gas Cooler	56 dB	+0 dB	-26 dB	+2 dB	-0 dB	-5 dB	26 dB
2	Carrier Compressor Pack (Enclosed)	52 dB	+0 dB	-27 dB	+2 dB	-0 dB	-8 dB	19 dB
3	Daikin RZAG 125 NV1 AC Unit (Enclosed)	55 dB	+0 dB	-29 dB	+2 dB	-0 dB	0 dB	29 dB
4	Daikin RZAG 125 NV1 AC Unit (Enclosed)	55 dB	+0 dB	-30 dB	+0 dB	-0 dB	0 dB	28 dB
Combined Noise Levels at Residential Façade:								33 dB(A)

5.2.2 Night Time (23:00 to 07:00)

Night Time (23:00 to 07:00)		Source	ISO 9613 – Part 2: 1996 Corrections					Assessment
Ref	Description	L_w	D_c	A_{div}	A_{gr}	A_{atm}	A_{bar}	L_p
1	Low Noise Gas Cooler	56 dB	+0 dB	-26 dB	+2 dB	-0 dB	-5 dB	26 dB
2	Carrier Compressor Pack (Enclosed)	52 dB	+0 dB	-27 dB	+2 dB	-0 dB	-8 dB	19 dB
Combined Noise Level at Residential Façade:								27 dB(A)

5.3. Assessment of Average Noise Levels (BS 4142: 2014 + A1: 2019)

BS 4142: 2014	Day Time - 07:00 to 19:00	Evening – 19:00 to 23:00	Night Time – 23:00 to 07:00
Specific Noise Levels	$L_{Aeq,1 \text{ hours}}$ 33 dB	$L_{Aeq,1 \text{ hours}}$ 33 dB	$L_{Aeq, 15 \text{ minutes}}$ 27 dB
Impulsivity Feature	+0 dB	+0 dB	+2 dB
Tonality Feature	+0 dB	+0 dB	+0 dB
Rating Noise Levels	$L_{Aeq,1 \text{ hours}}$ 33 dB	$L_{Aeq,1 \text{ hours}}$ 33 dB	$L_{Aeq, 15 \text{ minutes}}$ 27 dB
Background Noise Levels	$L_{A90,1 \text{ hours}}$ 44 dB	$L_{A90,1 \text{ hours}}$ 39 dB	$L_{A90, 15 \text{ minutes}}$ 30 dB
BS 4142 Assessment	-11 dB (Low Impact)	-6 dB (Low Impact)	-3 dB (Low Impact)

6. Conclusions...

6.1. Assessment Position

The 1st floor bedroom at the rear of 43 Andover Road is located between 5 m and 6 m from the dedicated plant area at the side of store where it is proposed to locate the replacement remote gas cooler and two new AC heat pumps.

6.2. Background Noise Measurements

Day Time (07:00 – 19:00)			Evening (19:00 – 23:00)			Night Time (23:00 – 07:00)		
L _{Amax,1h}	L _{Aeq,1h}	L _{A90,1h}	L _{Amax,1h}	L _{Aeq,1h}	L _{A90,1h}	L _{Amax,15m}	L _{Aeq,15m}	L _{A90,15m}
58 - 75 dB	50 - 57 dB	44 - 50 dB	53 - 77 dB	43 - 55 dB	39 - 46 dB	41 - 68 dB	38 - 53 dB	26 - 49 dB
Minimum Background		44 dB	Minimum Background		39 dB	Modal Background		30 dB

6.3. Criterion at Assessment Position

To comply with the revised version of the National Planning Policy Framework (“NPPF”) and the guidance within the Local Plan, the resultant noise levels at the nearest residential dwellings are below the minimum background noise levels when assessed in accordance with British Standard 4142: 2014 + A1: 2019.

6.4. Mitigation Measures

The plant has been designed to meet the specific requirements of the Local Authority and therefore additional acoustic mitigation measures will not be required.

6.5. Assessment of Noise Levels

Day Time (07:00 – 19:00)			Evening (19:00 – 23:00)			Night Time (23:00 – 07:00)		
L _{Aeq,1h}	L _{A90,1h}	BS4142	L _{Aeq,1h}	L _{A90,1h}	BS4142	L _{Aeq,1h}	L _{A90,1h}	BS4142
33 dB	44 dB	-11 dB	33 dB	39 dB	-6 dB	27 dB	30 dB	-3 dB

6.6. Conclusions

The resultant noise levels from the proposed mechanical equipment will result in noise levels that comply in full with the Local Plan and are at levels that are very unlikely to give rise to complaints from residents.

6.7. Uncertainty

Day Time (07:00 – 19:00)	Evening (19:00 – 23:00)	Night Time (23:00 – 07:00)
+1.71 dB (k=2, 95% Confidence)	+1.78 dB (k=2, 95% Confidence)	+2.14 dB (k=2, 95% Confidence)

7. Appendix A - BS 4142:2014 + A1: 2019 Information to Be Reported...

7.1. a) Competency

	Name	Role	Competency
1)	Mr. R. Scrivener	Director	Master of Science Degree in Acoustics and Noise Control (MSc) Member of the Institute of Acoustics (MIOA)

7.2. b) Source Under Investigation

1)	Source Number	Description		
	Source 1	Low Noise Gas Cooler 2.71m x 1.21m x 1.60m high 24 dB(A) at 10m		
	Source 2	Carrier Compressor Pack (Enclosed) 1.50m x 1.20m x 2.40m high 20 dB(A) at 10m		
	Source 3	Daikin RZAG 125 NV1 AC Unit (Enclosed) 1.75m x 1.10m x 1.66m high 23 dB(A) at 10m		
	Source 4	Daikin RZAG 125 NV1 AC Unit (Enclosed) 1,75m x deep x 1.66m high 23 dB(A) at 10m		
2) 3) 4) 5)	Description of Source	Source Location	Hours of Operation	Mode of Operation
	Source 1	Dedicated plant area at the side of store.	24-hour	Continuously on Demand
	Source 2			
	Source 3			
	Source 4			
	Description of Operation	Period	Conditions	Load
	All Sources	Day Time (07:00 to 19:00)	Ambient Temp 32°C	Maximum Load (100%)
		Evening (19:00 to 23:00)	Ambient Temp 28°C	Part Load (60%)
		Night Time (23:00 to 07:00)	Ambient Temp 24°C	Part Load (40%)
	Description of Premises	The Tesco Express is located on Andover Road with a small car park at the front of the store. Planning permission has been granted for new residential dwellings at the rear of the site on the former garage / workshop. The 1st floor bedroom window at the rear of 43 Andover Road is located around 6m from the replacement gas cooler and the two AC units repositioned on the flat roof at the side of the store.		

7.3. c) Subjective Impression of Source at Assessment Position

1)	Dominance	Source will not be dominant at residential facade
	Audibility	Source will not be audible at residential facade
2)	Residual Noise Sources	Residual noise due to local road traffic

7.4. d) Existing Contexts

	Type of Receptor	Period	Sensitivity	Description
1)	Residential	Day Time (07:00 to 19:00)	Low	Noise can disturb outside amenity space and internal living space
		Evening (19:00 to 23:00)	Moderate	Noise can interrupt people trying to get to sleep
		Night Time (23:00 to 07:00)	High	Noise can disturb sleeping

7.5. e) Relative Positions

1)	Assessment Position	1 st floor bedroom at the rear of 43 Andover Road.		
		BS 4142:2014 Criteria	Details	Compliance with Criteria
		Section 6	1.0m from façade (external)	Position is valid
2)	Source Measurement	The source sound power levels were supplied by the client. It is believed the sound power levels were established in accordance with BS EN 13487:2003.		
	Justification	The client supplied the noise levels for the proposed plant.		
3)	Background Position	At the rear of the site adjacent to the garage / workshop.		
	Justification	BS 4142:2014 Criteria	Details	Compliance with Criteria
		Section 6.2	3.5m to any reflecting surface	Complies
		Section 6.2	Height 1.2m to 1.5m	Complies
		Section 6.2	1 st floor 1m to facade	Not applicable
		Section 6.2	Measurement Height	3.5m
			Distance to Reflecting Surface	1.0m
		To record remote background levels, the noise meter had to be left in a secure position. The position represented the assessment position within the constraints of the site.		
4)	Topography, surfaces etc.	Hard and Flat		
5)	Relative Distances	The plant is located approximately 5 to 6 m from the assessment position.		
6)	Dimensioned sketch	See maps and images.		

7.6. f) Noise Measurement Equipment Calibration

1)	Type	Sound Level Meter	Microphone	Calibrator
		KRE/07/01	KRE/07/02	KRE/07/04
2)	Manufacturer	Casella CEL 63X	Casella CEL 251	Casella CEL 120/1
3)	Serial Number	2206846	00663	2839212
4)	Certificate Number	Certificate: U44755	Certificate: U44755	Certificate: U48268
	Calibration Due Date	04/07/2025	04/07/2025	04/07/2025

7.7. g) Noise Measurement Equipment Operation Test

1)	Ref. Level of Calibrator	94 dB
2)	Meter Reading Before	94 dB – Meter operation checked. Meter in good working order.
	Meter Reading After	94 dB - Meter operation checked. Meter in good working order.

7.8. h) Weather Conditions

1)	Wind Speed	See weather information
	Wind Direction	
2)	Temperature Inversion	Unlikely to have occurred
3)	Precipitation	None – See section 3.1
4)	Fog	None
5)	Wet Ground	Not within the measurement period – See section 3.1
6)	Frozen Ground or Snow	Not within the measurement period – See section 3.1
7)	Temperature	See section 3.1
8)	Cloud Cover	Partly Cloudy

7.9. i) Date of Measurements

1)	Source Measurements	Unknown
	Background Measurements	16/04/2025

7.10. j) Measurement Time Interval

1)	Source Measurements	$T_m = 15 \text{ minutes}$	
	Background Measurements	Day Time (07:00 to 19:00)	$T_m = 12 \text{ hours}$
		Evening (19:00 to 23:00)	$T_m = 4 \text{ hours}$
		Night Time (23:00 to 07:00)	$T_m = 8 \text{ hours}$

7.11. k) Reference Time Interval

1)	Reference Time Interval	Day Time (07:00 to 19:00)	$T_r = 1 \text{ hour}$
		Evening (19:00 to 23:00)	$T_r = 1 \text{ hour}$
		Night Time (23:00 to 07:00)	$T_r = 15 \text{ minutes}$

7.12. l) Specific Noise / m) Background Noise / n) Rating / o) Assessment / p) Conclusions

These details are all included within the body of the report and are not replicated within this section.

END OF REPORT (1st and last page not numbered)



KR Associates (UK) Ltd
Quietly confident...



Southampton: 02380 55 04 55