

Window Schedule:

Note:	Condition (post-fire):
WG01	Iron lattice casement with pintle hinges in timber frame. Single glazed, some broken glazing
WG02	As WG01
WG03	As WG01, Significant damage to casement
WG04	As WG01
WG05	As WG01
WG06	Door lost in fire, currently boarded opening
WG07	Modern rebated timber casements in timber framed. Single glazed, modern glass, putty glazing beads
WG08	As WG07
WG09	As WG07
WG10	As WG07
WG11	uPVC Frame and casement, DGUs
WG12	Timber casement wth timber frame, clay tiled sub sill, completly lost to fire
WF13	Iron lattice casement with pintle hinges in timber frame. Single glazed, some broken glazing
WF14	As WF13
WF15	As WF13
WF16	As WF13
WF17	As WF13
WF18	Steel casement in steel frame with timber sub-frame, modern throw hinges, side hung. All glazing lost in fire.
WF19	Frame and glazing completely destroyed. Assumed to be as WF20
WF20	Modern rebated timber casements in timber framed. Single glazed, modern glass, putty glazing beads frame – signifcicant fire damage
WF21	As WF20
WF22	Metal fixed casement in timber sub frame with peg joints

Action:
Retain and repair
Retain
Retain and repair
Retain and repair
Retain and repair
Replace (to match existing)
Retain and repair
Retain and repair
Retain and repair
Retainand repair
Cob infill and lime render to match existing
Retain and repair (new timber frame required)
Retain and repair (new timber frame required)
Retain and repair (new timber frame required)
Retain and repair (new timber frame required)
Retain and repair (new timber frame required)
Cob infill and lime render to match existing
Replace to match WG07. See Window detail 301
Replace to match WG07. See Window detail 301
Replace to match WG07. See Window detail 301
Retain and repair

PLANNING & LISTED BUILDING CONSENT Notes

- A. All Drawings to be read in conjunction with supporting Design & Heritage Statement
- B. Do not scale from this drawing use figured dimensions only. All dimensions are to be checked on site.
- C. Contractor to report any discrepancies, drawing errors and omissions to Chalk Architects immediatley
- D. All structural elements to Structural Engineer's details and specifications
- E. All work subject to Listed Building Consents & Planning Approval including conditions issued by Local Planning Authority
- F. All work to comply with guidance within relevant UK Building Regulations Approved Documents
- G. All work subject to the Party Wall Act etc 1996.

A	19/02/2026	Infilled windows
Revision:	Date:	Reason:

RS3 – PLANNING & LBC

Hackthorne Cottage (SP4 9DP)

25-16-300A

Window Schedule

Scale:	Paper size:	Date:	Drawn by:	Checked by
NTS	A3	04/02/2026	EB	JM



Chalk.