

To:	Sarah Hill	From:	James Playfair
------------	------------	--------------	----------------

Planning App Ref:	PL/2025/10022
Service Ref:	Drainage
Date:	23 February 2026

PROPOSAL

Outline planning permission: Some matters reserved

Outline application with some reserved matters for the erection of two detached dwellings and garages with access from development to the north (Access and Layout)

SITE LOCATION

Land fronting Southwest of Witt Road , Winterslow, Salisbury

SUMMARY OF THE CONSULTEE POSITION

Object	
Holding Objection: Further information required	
Support	
No comment	
No objection	
No objection subject to conditions	X
Consultation not required	

APPLICATION DOCUMENTS REVIEWED

- Reply to LLFA Comments

ASSESSMENT OF THE PROPOSAL

Context

On the 16th January 2026, the LLFA stated that the applicant provide the following documentation and information as a drainage strategy had not been defined

- Evidence that the [surface water disposal hierarchy](#) has been applied.
- The strategy mimics the existing drainage characteristics of the site by retaining and utilising any existing drainage features.
- Soakaway testing in accordance with BRE365, and groundwater level monitoring (taking into account seasonal variations).
- If infiltration is proposed, it is implemented in manner that does not create an offsite impact, particularly if there are reports of groundwater flooding in the area.
- Existing pre and post development runoff rates for the site, in accordance with Wiltshire Council's betterment policy update, which can be found [here](#).
- Calculations that demonstrate the sizing of any attenuation/ SuDS features and cross section drawings of these features.
- Pre and post development exceedance routing that demonstrates flood risk is not increased elsewhere.

- Evidence that the finished floor levels are above the maximum predicted 100-year flood level or if no flooding is predicted, at a sufficient height above the SW drainage cover levels.
- Evidence that the proposed drainage design provides a sufficient level of water treatment.
- Consent for any outfalls from the proposed drainage systems into a public sewer or other drainage system not owned by the applicant.
- Details of how the proposed and existing drainage features on the site will be maintained and managed after completion with confirmation from the relevant authority that they will adopt any systems that are being offered for adoption.
- If access to the site is predicted to flood, an emergency plan must be agreed with Wiltshire Council. Guidance on the preparation of an emergency plan can be found [here](#).

Assessment

All matters raised have been addressed by the applicant to a satisfactory standard, and it is acknowledged that any remaining details can be appropriately secured through planning conditions.

RECOMMENDATION

No objection subject to the following conditions

- Refined soakaway calculations based on geotechnical investigations at the detailed design stage.
- Soakaway cross sections based on the above.
- Explicit details of how the proposed and existing drainage features on the site will be maintained and managed after completion at the detailed design stage.

INFORMATIVES

The applicant is reminded of their riparian responsibilities for maintaining flows within ordinary watercourses. Guidance on riparian ownership can be found here [Owning a watercourse - GOV.UK \(www.gov.uk\)](https://www.gov.uk/owning-a-watercourse)"

Prior to any works commencing on the upstream drainage network, the approved outfall structure and flow control device shall be fully constructed, tested, and commissioned. No discharge to the receiving system (including watercourses, waterbodies, sewers, or drains) shall occur until these measures are operational to ensure compliance with agreed discharge rates and prevent an increase in flood risk elsewhere.

To aid in the development of compliant drainage strategies, the following are recommended without prejudice. These are based on the [National Standards for SuDS](#). We would recommend also utilising the best practice guidance within *The SuDS Manual*, and *Getting SuDS Right from the Start*:

Standard	Best Practice Considerations
Standard 1 – Drainage Hierarchy	• Retain and enhance existing natural drainage features where possible. • Use site layout to maximize opportunities for infiltration and above-ground conveyance. • Identify how communal rainwater harvesting can be utilised to help improve viability of inclusion. • Identify whole-life cost-benefits such as water bill reductions for implementing rainwater harvesting.
Standard 2: Interception	• Use green roofs, permeable paving, rain gardens, and bioretention to maximize interception. • Distribute source control features throughout the site for maximum effectiveness. • Provide a maintenance plan to ensure interception features remain effective.
Standard 3: Management of Extreme Rainfall and Flooding	• Use topographical surveys to identify and preserve natural overland flow routes. • Design SuDS features with freeboard and overflow routes. • Ensure safe access and egress during extreme events. • Consider overland flows originating from outside redline boundary • Consider how the drainage systems will perform in the event of blockage and failure
Standard 4: Water Quality	• Use vegetated SuDS (swales, ponds, wetlands) for effective pollutant removal. • Include forebays or sediment traps upstream of main SuDS features. • Provide a maintenance plan for regular removal of silt and debris.
Standard 5: Amenity	• Use gentle side slopes, accessible paths, and seating to make SuDS features usable and attractive. • Involve local communities in the design of SuDS spaces.
Standard 6: Biodiversity	• Design SuDS to create wetland mosaics, wildlife corridors, and habitat connectivity. • Consider how SuDS can help provide wider BNG benefits / credits to the site
Standard 7: Construction, Operation, Maintenance, Decommissioning, and Structural Integrity	• Plan for safe access for maintenance. • Include decommissioning plans for temporary features.

The table below stipulates the information typically required at each application stage. Provision of the correct information will expedite the processing of applications by the drainage team.

Pre-app	Outline	Full	Reserved matters	Discharge of conditions	Document to be submitted
✓	✓	✓			Flood Risk Assessment / Statement
✓	✓	✓			Drainage Strategy / Statement & sketch layout plan
	✓				Preliminary "Outline" hydraulic calculations
	✓	✓			Ground investigation report (for infiltration)
	✓	✓	✓	✓	Evidence of third party agreement for discharge to their system (consent to discharge)
		✓		✓	Maintenance program and on-going maintenance responsibilities
		✓	✓	✓	Detailed flood & drainage design drawings
		✓	✓	✓	Evidence of measures to prevent pollution of the receiving groundwater and/or surface waters
		✓	✓	✓	Drawings showing conveyance routes for flows exceeding the 1 in 100 year plus climate change