

Application Number:	PL/2026/00701
Location:	High View, Idmiston Road, Porton, Salisbury, SP4 0LD
Proposal:	Discharge of conditions 6 (CEMP), 9 (Archaeological work), 10 (Construction Management Statement), 14 (Tree protection) and 15 (Landscape work) of PL/2025/04645.

I refer to the Construction Site Plan received following the request in the previous HDM consultation response dated 25th February 2026.

The Construction Site Plan indicates the areas set aside for the site compound and materials storage; contractor parking; and materials set down and storage area. The plan also indicates the proposed location for wheel washing, which is identified as a manual wheel wash.

Whilst the plan is not too detailed, and does not indicate a parking layout or swept paths, it is considered that there is sufficient space for parking and manoeuvring within the site and within the additional areas available within the farmyard, such that there would be no adverse impact on the operation of the highway.

It is therefore recommended that condition 10 be discharged.

Amanda Hall
Highways Development Management Engineer