



Application Reference Number: PL/2026/00781

Decision Date: 09/03/2026

Applicant:	SSE Martigny House, 61 Spa Road , Melksham, SN12 7NU
Particulars of Development:	Upgrade 5 spans of 11KV overhead lines to 3rd wire and upgrade the existing pole mounted transformer from 100kva to 200kva and adding a H pole.
At:	Greenacre Farm Broomfield, Yatton Keynell, Chippenham, Wiltshire, SN14 7JY

No Objections Raised

Nic Thomas - Director of Planning, Economy and Regeneration