

## **Highway Development Management Consultation Response**

**Planning Application Ref:** PL/2025/09655

**Site Address:** 19 Rodbourne Road, Corston, Malmesbury, SN16 0HA.

**Proposal:** Proposed driveway

**Date of Consultation Response:** 09/03/2026

I refer to the above planning application dated 05/12/2025 seeking permission for a proposed driveway. Further information has been supplied to satisfy the previous request for demonstration of visibility from the new access.

The site has existing frontage onto Rodbourne Road, a C classified section of public highway subject to a speed limit of 30mph. The proposals include alterations to the public highway and as such a Licence or Permit will be required.

Plans have been submitted which detail a 4m wide driveway with drainage across the frontage. It is assumed that this would be required to prevent surface water from the driveway from entering the public highway. A 2m hardstanding is now indicated for the initial section of driveway, and it has now been demonstrated that a 2m x 43m splay can be achieved with no obstructions over 900mmm.

It is therefore considered that no highway objection be raised subject to the following informative:

### **INFORMATIVE - VEHICLE CROSSOVERS**

The application involves an extension to the creation of a new vehicle access. The consent hereby granted shall not be construed as authority to carry out works on the highway. The applicant is advised that a licence will be required from Wiltshire's Highway Authority before any works are carried out on any footway, footpath, carriageway, verge or other land forming part of the highway. Please contact our Vehicle Crossing Team on [vehicleaccess@wiltshire.gov.uk](mailto:vehicleaccess@wiltshire.gov.uk) and/or 01225 713352 or visit their website at <http://wiltshire.gov.uk/highways-streets> to make an application.

If you have any queries regarding the above advice, please contact:  
[HighwaysDevelopment@wiltshire.gov.uk](mailto:HighwaysDevelopment@wiltshire.gov.uk)