

To:	Samantha Stockley	From:	Drainage Team
------------	-------------------	--------------	---------------

Planning App Ref:	PL/2026/01476
Service Ref:	Drainage
Date:	09/04/2026

PROPOSAL

Retrospective application for engineering operations comprising alterations to land levels and formation of hardstanding.

SITE LOCATION

South Farm, Water Eaton, Swindon, SN6 6JU

SUMMARY OF THE CONSULTEE POSITION

Object	
Holding Objection: Further information required	
Support	
No comment	
No objection	
No objection subject to conditions	X
Consultation not required	

APPLICATION DOCUMENTS REVIEWED

- Application Form
- Cover Letter
- Site Location and Access Route
- Hardstanding Area Detail
- Section View

ASSESSMENT OF THE PROPOSAL

Context

In planning terms, flood risk refers to the potential for development to increase the likelihood or severity of flooding on-site or elsewhere, while drainage considerations relate to the capacity of the site and surrounding infrastructure to manage surface water runoff in a sustainable and effective manner.

The local planning authority must be satisfied that the proposed development will not increase flood risk, either on-site or elsewhere, and that surface water will be managed in a sustainable and coordinated manner.

Where necessary, planning conditions or legal agreements may be used to secure the implementation, maintenance, and monitoring of SuDS and other drainage infrastructure.

Assessment

The SFRA identifies the site as being within Flood Zone 1 with a low risk of fluvial, pluvial and groundwater flooding.

The proposal is a retrospective application for land-level alterations and a compacted crushed-stone hardstanding at South Farm, but the application does not confirm how surface water will drain, and because compacted crushed stone can behave as effectively impermeable, there is a potential risk of runoff affecting neighbouring land without further clarification.

RECOMMENDATION

No objection subject to conditions

1. **No development shall take place until a surface water drainage strategy, complying with Wiltshire Council requirements, NPPF, PPG and the National Standards for SuDS has been submitted to and approved in writing by the Local Planning Authority.**

In order to discharge the above drainage condition the following additional information must be provided:

- Confirm if the compacted crushed-stone hardstanding is permeable and explanation on how surface water will drain to ensure no uncontrolled runoff affects neighbouring land.
- The applicant should provide details of both pre- and post-development overland surface-water flow paths to demonstrate that the proposed hardstanding will not alter runoff patterns or increase flood risk to neighbouring land.

INFORMATIVES

- The EA's standing advice for minor extensions will apply.
- In line with the NPPF and National Standards for SuDS, the applicant should seek to use SuDS wherever practicable as part of the surface water drainage strategy.
- Any new connections to sewers will be subject to S106 agreement under the Water Industry Act with the Sewerage Undertaker.

RELEVANT PLANNING POLICY & GUIDANCE

National Planning Policy Framework (NPPF) [NPPF December 2024 Link](#)
Planning and Flood Risk (Paras 170–182)

Wiltshire Core Strategy – Adopted January 2015 [Wiltshire Core Strategy Link](#)
Core Policy 67 requires that all new development must address flood risk from all sources and not increase flood risk elsewhere. It supports the use of Sustainable Drainage Systems (SuDS) and requires that developments demonstrate how surface water will be managed sustainably.

Wiltshire Local Plan (emerging) [Local Plan Review Link](#)
Development must avoid high flood risk areas using the sequential approach. Proposals require a Flood Risk Assessment, Surface Water Drainage Strategy, and Groundwater Assessment where relevant. All schemes must include Sustainable Drainage Systems (SuDS), with major developments achieving a 30% reduction in runoff compared to greenfield rates, following the surface water discharge hierarchy.

Culverting and building over watercourses is discouraged, and natural drainage features should be retained or restored. Drainage strategies must ensure safety during extreme flood events (1-in-100-year + climate change) and provide safe access/egress. SuDS should also deliver biodiversity, amenity, and water quality benefits.

Supplementary Planning Documents

Wiltshire Council Drainage Betterment Strategy (2024) [SPD Link](#)
This technical guidance outlines expectations for surface water discharge hierarchy, attenuation, exceedance routes, water quality, and post-development monitoring.

Wiltshire Design Guide (March 2024) [SPD Link](#)
Includes principles of good design, including integration of SuDS and flood resilience.

Other Relevant Policies and Guidance

Planning Practice Guidance (PPG) – Flood Risk and Drainage [Guidance Link](#)
Covers detailed expectations for flood risk assessments, SuDS design, discharge hierarchy, sequential testing and climate change allowances.

Wiltshire SFRA (2024) [SFRA Link](#)
This document underpins the Sequential and Exception Test application and provides site screening evidence.

Section 19 Flood Investigation Reports [Section 19 Reports Link](#)
These documents summarise investigations into significant local flood incidents and establish what caused the flooding, how authorities responded, and actions needed to prevent future floods.

National Standards for Sustainable Drainage Systems (SuDS) June 2025 [Guidance Link](#)
Establishes mandatory criteria for runoff destination hierarchy, interception, flood resilience, water quality, amenity, biodiversity, and long-term maintenance for all new developments in England.

SuDS Manual (CIRIA C753)

This document set outs design principles, especially where attenuation, exceedance routing, and water quality are discussed.

Infiltration drainage design must be supported by ground investigations, including infiltration testing in accordance with *British Research Establishment (BRE) Digest 365 – Soakaway Design*, and groundwater level monitoring that accounts for seasonal variation.