

**Applicant to Drainage – accompanying Plans 7061-C-100 REV A and
7061-C-106 REV**

The developer should provide the following information as part of future planning applications in accordance with Wiltshire Council requirements, NPPF, PPG and Non Statutory Technical

Standards for SuDs

- *Soakaway testing in accordance with BRE365, and groundwater level monitoring (taking into account seasonal variations) to prove that disposal via soakaway is feasible*

SDS Response 07/04/2026 - refer to report 7061-RP01 as already provided. Infiltration testing results are appended and the groundwater level is referenced by the relation ship to borehole records showing a deep groundwater level

- *Calculations that demonstrate the sizing of any attenuation/ SuDS features and cross section drawings of these features based on recorded infiltration rates and runoff volumes.*

SDS Response 07/04/2026 - refer to report 7061-RP01 as already provided. Attached layout and drainage construction details included

- *Pre and post development exceedance routing that demonstrates flood risk is not increased elsewhere.*

SDS Response 07/04/2026 - refer to report 7061-RP01 as already provided.