

To:	Georgina Wright	From:	Drainage (Barney Taylor)
------------	-----------------	--------------	--------------------------

Planning App Ref:	PL/2026/01523
Service Ref:	Drainage
Date:	16/04/2026

PROPOSAL

Change of use of land and conversion of agricultural building to form 1 bed dwelling (Use Class C3) with associated parking and residential curtilage (revised scheme to the Class Q permission ref: PL/2025/08124). Single storey front extension to new dwelling. Erection of agricultural shed. New Sewage Treatment Plant and associated works.

SITE LOCATION

Vineview Cottage, Tytherley Road, Winterslow, Salisbury, SP5 1PZ

SUMMARY OF THE CONSULTEE POSITION

Object	
Holding Objection: Further information required	
Support	
No comment	
No objection	x
No objection subject to conditions	
Consultation not required	

APPLICATION DOCUMENTS REVIEWED

- *Application Form*
- *Cover Letter*
- *Percolation Test Report*
- *Planning Statement*
- *Proposed STP & Change of USE 1 & 2*
- *Sewage Treatment Plan*
- *Site Overview*
- *Site Plan*
- *Treatment Performance Results*

ASSESSMENT OF THE PROPOSAL

Context

In planning terms, flood risk refers to the potential for development to increase the likelihood or severity of flooding on-site or elsewhere, while drainage considerations relate to the capacity of the site and surrounding infrastructure to manage surface water runoff in a sustainable and effective manner.

The local planning authority must be satisfied that the proposed development will not increase flood risk, either on-site or elsewhere, and that surface water will be managed in a sustainable and coordinated manner.

Where necessary, planning conditions or legal agreements may be used to secure the implementation, maintenance, and monitoring of SuDS and other drainage infrastructure.

Assessment

The application has been supported with a Site-Specific Flood Risk Assessment (FRA). It should be noted that our comments below are reliant on the accuracy and completeness of the FRA and we do not take any responsibility for incorrect data or interpretation made by the authors.

The LLFA are confident the change of use & proposed soakaway features will not increase flood risk to people or property at the site, or adjacent land. Therefore, we have no objection to this development.

The applicant has claimed that the proposed PTP is compliant with Building Regulations and General Binding Rules – this should be checked by the council's building control department.

RECOMMENDATION: No Objection

The proposed development will not increase flood risk to people & property. The applicant must ensure the soakaway is maintained in accordance with the guidance linked beneath.

INFORMATIVES

The application states that foul drainage will discharge to a private treatment system. This requires consultation with the EA, see the [EA guidance](#). The applicant can also contact the EA for pre-planning advice at swx.sp@environment-agency.gov.uk.

In addition, the applicant is required to demonstrate that the proposed discharge from the package treatment plant is in full compliance with the General Binding Rules (for discharge to a drainage field) or that an Environmental Permit from the EA has been obtained.

The applicant must ensure a copy of the drainage strategy & maintenance regime are included in the title deeds of the property

RELEVANT PLANNING POLICY & GUIDANCE

National Planning Policy Framework (NPPF) [NPPF December 2024 Link](#)
Planning and Flood Risk (Paras 170–182)

Wiltshire Core Strategy – Adopted January 2015 [Wiltshire Core Strategy Link](#)
Core Policy 67 requires that all new development must address flood risk from all sources and not increase flood risk elsewhere. It supports the use of Sustainable Drainage Systems (SuDS) and requires that developments demonstrate how surface water will be managed sustainably.

Wiltshire Local Plan (emerging) [Local Plan Review Link](#)
Development must avoid high flood risk areas using the sequential approach. Proposals require a Flood Risk Assessment, Surface Water Drainage Strategy, and Groundwater Assessment where relevant. All schemes must include Sustainable Drainage Systems (SuDS), with major developments achieving a 30% reduction in runoff compared to greenfield rates, following the surface water discharge hierarchy.

Culverting and building over watercourses is discouraged, and natural drainage features should be retained or restored. Drainage strategies must ensure safety during extreme flood events (1-in-100-year + climate change) and provide safe access/egress. SuDS should also deliver biodiversity, amenity, and water quality benefits.

Supplementary Planning Documents

Wiltshire Council Drainage Betterment Strategy (2024) [SPD Link](#)
This technical guidance outlines expectations for surface water discharge hierarchy, attenuation, exceedance routes, water quality, and post-development monitoring.

Wiltshire Design Guide (March 2024) [SPD Link](#)
Includes principles of good design, including integration of SuDS and flood resilience.

Other Relevant Policies and Guidance

Planning Practice Guidance (PPG) – Flood Risk and Drainage [Guidance Link](#)
Covers detailed expectations for flood risk assessments, SuDS design, discharge hierarchy, sequential testing and climate change allowances.

Wiltshire SFRA (2024) [SFRA Link](#)
This document underpins the Sequential and Exception Test application and provides site screening evidence.

Section 19 Flood Investigation Reports [Section 19 Reports Link](#)
These documents summarise investigations into significant local flood incidents and establish what caused the flooding, how authorities responded, and actions needed to prevent future floods.

National Standards for Sustainable Drainage Systems (SuDS) June 2025 [Guidance Link](#)

Establishes mandatory criteria for runoff destination hierarchy, interception, flood resilience, water quality, amenity, biodiversity, and long-term maintenance for all new developments in England.

SuDS Manual (CIRIA C753)

This document set out design principles, especially where attenuation, exceedance routing, and water quality are discussed.

Infiltration drainage design must be supported by ground investigations, including infiltration testing in accordance with *British Research Establishment (BRE) Digest 365 – Soakaway Design*, and groundwater level monitoring that accounts for seasonal variation.