

Site Number	RAG
(45 part 2 of 2). & (46 part 1 of 2). CRIC E5 11KV. Surveyor and landowner to be present on day of cutting.	RED

Affected	LV		11kV	2	33kV	
Spans:	132kV		275kV		400kV	

Tree Programme – Landowner Consent Form



Landowner Details			
Feeder Name / Voltage	CRIC E5 Hv	Landowners Name	Mrs. Krajewski
Transformer Name	P2 (HR) CRICKLADE.	Address	Brook house 72 high St, Cricklade. SN6 6DD.
Grid Ref	SU102939.		
NRN	P185-186		
What3Words	Refriand.whiplash.studio. ST102939		
SSEN Contact Name	Sam McCubbin-Western	Landowners Contact Number	
SSEN Contact Number		Landowners Email Address	
Restricted Cut QSI Approval		QSI Signature	
QSI Approval – Other			

Work to be carried out					
Site 45:					
G1. Cat A/C. Mixed species growing under and to side of ohl. To include Hazel, sycamore lime, Oak. Side Reduce to previous cut points where possible. To gain restricted 3.5m safety clearance. Please be sympathetic to trees whilst gaining these clearances.					
Dealing with Arisings: Chip on site I discreet area as per landowner instructions on day of shutdown. Stack log neatly.					
Is traffic management required:					
Is this a RAIL site: No					
SSSI	No	TPO Conversion	Yes	Nesting Birds	No
Protected Species	No	Area	No	Other	
Ecoplugs to be used	No				

Team Staff on Site 3 x Men 4 x Hours			
Restricted Cut	No	Recut Year	2028
Date Completed		Time Taken	

Work to be carried out

Site 46:
G2, Cat A. Damson. Height reduce/side reduce to gain a 3.5m restricted cut safety clearance from the 11kv overhead electrical network.

T1, T2, T3. Cat A/C. Field Maple, Damon x2 COPPICE TO GROUND LEVEL.

G3, Cat A. Goat Willow, Field Maple, Balsam Poplar. Height reduce side reduce to gain a 3.5m restricted cut safety clearance.

Dealing with Arisings:
Chip waste neatly on site in discreet areas away from watercourses and meadow.
Stack log neatly.

Is traffic management required:

Is this a RAIL site: No

SSSI	No	TPO Conversion	Yes	Nesting Birds	No
Protected Species	No	Area	No	Other	
Ecoplugs to be used	No				
Team Staff on Site 4 x Men 4 x Hours					
Restricted Cut	No	Recut Year	2028		
Date Completed		Time Taken			

Customer Consent

Landowners Comments / Requests

Please give 1 weeks notice prior to cutting. Surveyor and landowner to present on day of cutting.

I hereby authorise Southern Electric Power Distribution plc and / or its sub contractors to carry out the Tree and Vegetation Clearance as outline above. I understand that I will not be charged for this work. By signing this form, I confirm I am the landowner and approve this work

Landowner Signature		Date	17/03/2026
Authorised Person's Signature		Relationship to Landowner	

For information on how we collect and process your data, please see our privacy, www.ssen.co.uk/PrivacyNotice/. If you do not have access to our website or would like a hard copy sent, please ask a member of staff.

Risk Assessment	
HAV points for this site - Calculated from GN020 HAND-ARM Vibration Exposure Information	5
List details of hazards found whilst surveying and recommend control measures.	
Hazards	Controls
Soft Ground	GIVE PRIOR NOTICE TO LANDOWNER
Other: Meadow	Other: Foot and track chipper only.
Other: Water Manhole cover.	
ALL WORKS MUST BE CARRIED OUT FOLLOWING Birch GN020 AND BUSAP5 HAVS ACTION PLAN	
Work Method Statement	

Site Plan & Photos








Chosen work method including justification			
CAT A: BRANCHES PROTRUDE THROUGH VZ ABOVE VZ AND ABOVE LZ.- SD REQUIRED			
Changes to the Work Method Statement authorised by			
Revised changes to the chosen work method including justification			
Work Method Statement completed by	Sam McCubbin-Western	Date	17/03/2026
Working Party Agreement		Date	

Chosen work method including justification			
CAT A: BRANCHES PROTRUDE THROUGH VZ ABOVE VZ AND ABOVE LZ.- SD REQUIRED			
Changes to the Work Method Statement authorised by			
Revised changes to the chosen work method including justification			
Work Method Statement completed by	Sam McCubbin-Western	Date	17/03/2026
Working Party Agreement		Date	


Tree Cutting - Work Method Statement						
Site No	46	Map No	1	NRN	P185-186	
Site No	45	Map No	1	NRN	P185-186	
Access Route / Parking Facilities Access to site on foot from 7 abingdon court Lane. SN66BL. ///impose.twins.rebel SU102938. Vehicle/chipper and foot access from No'17 Brook House///sunset.something.widget SU101939						
Tree Category	A, C				PMR 1 HIT	
Will this site be cut using mechanisation?	No		If so, what type? ,			
Do we need to work at height?	Yes	Will the trees be straight felled?		No	Will we shroud the LV?	N/A
Are we using the correct access method?	Insulated Rods / High pole power pruner?			Yes	Will we use a MEWP?	No
	Climbing with hand pruning saw?			Yes	Climbing with chainsaw?	Yes
Site Plan						
Plant / Tools Chainsaw (Ground), Chainsaw (Top Handle), Insulated Rods, Hand Pruning Saw, Power Pruner, Hedge Cutter, Long Handled Loppers, Tracked Chipper *OTHER (Please Specify below						
Environment Watercourse						
Wildlife Livestock, Nesting Birds						

SAFETY IS NO ACCIDENT: IF IN DOUBT, SPEAK UP

A RISK ASSESSMENT MUST BE CARRIED OUT BY ALL STAFF FOR ALL ELEMENTS OF WORK COVERED BY THIS WORK METHOD STATEMENT

Tree Cutting HV Live Line Justification	FO-PS-353
--	------------------

Circuit	CRIC E5		Nearest transformer or NRN	P185-186	
Location	///snored.boardroom.airbag SU102938	Site No	(45 part 2 of 2). & (46 part 1 of 2). CRIC E5 11KV. Surveyor and landowner to be present on day of cutting.	Date	17/03/2026



Point of work risk assessment on site Emergency details	Surveyor name	Sam McCubbin-Western
Location of works: <i>including address and postcode</i> Brook house 72 high St, Cricklade. SN6 6DD.	NRN circuit, feeder details Grid reference	P185-186 SU102939.

SSEN Emergency control number	0800 210 999 SEPD (SOUTH) 0800 300 999 SHEPD (NORTH)
UK Emergency services	999 or 112
Nearest NHS A&E location and land line number	The Great Western Hospital Marlborough Road, Swindon SN3 6BB 01793 604020
CASEVAC helicopter landing point	At site in large open field ///towers.upholding.blazed SU102938
Ground Ambulance site access route	Access to site on foot from 7 abingdon court Lane. SN66BL. ///impose.twins.rebel SU102938. Vehicle/chipper and foot access from No'17 Brook House///sunset.something.widget SU101939
Emergency contact number	Jon Jones – 07777 520892 Danny Birch – 07495 540734