

Application Number:	PL/2026/01103
Location:	Rosewood, Salt Lane, Winterbourne Gunner, Salisbury, SP4 6LW
Proposal:	Proposed Single Storey Detached Garage

[SP4 6LW - Google Maps](#)

I refer to the additional plans received in respect of the above planning application, in response to the previous HDM comments of the 24th March 2026 in which details of the boundary treatment were sought.

The frontage boundary wall to Salt Lane is indicated as 900mm in height, which would provide for an acceptable level of junction and intervisibility, having regard to the nature of the access lane.

Summary and Recommendations

The proposed relocation of the vehicular access to serve the site and the amendments to the car parking arrangements are considered acceptable. The boundary treatment provides for a 900mm high wall either side of the access opening, which is considered acceptable.

It is therefore recommended that no highway objection is raised.

Amanda Hall
Highways Development Management Engineer