



**Customer Name:** David Brain Partnership

**Site Address:** Beacon Centre, Solar Way, Amesbury, SP4 7SZ

**Date:** 18th March 2026

**Description:** Soakaway Investigation



**Katie Maber**

**Tel: 07904 918481**

**Director**

**Email: [cloacina.services@outlook.com](mailto:cloacina.services@outlook.com)**

## Investigation Summary

---

We attended site and located the soakaway access covers as shown on the plan. The soakaways are around 2.2m deep and constructed as concrete preformed chambers with preformed soakaway holes. The chambers are surround with clean granular stone. There is very minimal silt build up in the line and the chambers, and the soak aways are working efficiently. In the chambers you can see tide marks where the water is rising to before it soaks away and this is approximately 700mm deep, proving the soak aways are working well. We did not note any defects at the time of our survey.

See photos attached below:



**SOAKAWAY COVER 3**

**SOAKAWAY COVER 3**



**SOAKAWAY COVER 2**

