



CLOACINA
SERVICES LTD

Customer Name: David Brain Partnership

Site Address: Beacon Centre, Solar Way, Amesbury, SP4 7SZ

Date: 18th March 2026

Description: Soakaway Investigation



Katie Maber

Tel: 07904 918481

Director

Email: cloacina.services@outlook.com

Investigation Summary

We attended site and located the soakaway access covers as shown on the plan. The soakaways are around 2.2m deep and constructed as concrete preformed chambers with preformed soakaway holes. The chambers are surround with clean granular stone. There is very minimal silt build up in the line and the chambers, and the soak aways are working efficiently. In the chambers you can see tide marks where the water is rising to before it soaks away and this is approximately 700mm deep, proving the soak aways are working well. We did not note any defects at the time of our survey.

See photos attached below:





SOAKAWAY COVER 1

