

06 May 2026

Dear Sir/Madam

TOWN AND COUNTY PLANNING ACT 1990 (as amended)
APPROVAL OF DETAILS RESERVED BY CONDITION

Application No:	PL/2026/00999
Proposal:	Discharge of Condition 4 (Water Efficiency in River Avon Catchments) of PL/2023/04116 - Conversion of the two existing farm buildings into a holiday let. The buildings will be linked to form bedrooms to the north building and living accommodation to the south.
Site Address:	The Piggery, Knowle Farm, Church Street, Bowerchalke, Salisbury, SP5 5BP
On Behalf Of:	ML Architecture Knowle Farm, Burcombe Lane, Burcombe, Salisbury, Wiltshire, United Kingdom, SP5 5BP

I refer to your application for the discharge of condition(s) attached to the above planning permission dated 12 March 2026. After careful consideration, the following decision has been made:

Condition submitted for consideration:

(4) The overnight development hereby approved shall be designed to ensure it does not exceed 110 litres per person per day water consumption levels (which includes external water usage) and a water efficiency assessment should be submitted.

Before the development is brought into use, a water efficiency report certifying that this standard has been achieved shall be submitted to the local planning authority for its written approval.

REASON: To ensure compliance with the prevailing mitigation strategy for nutrient neutrality in the water catchment within which this development is located.

A water efficiency calculation will be needed to discharge this condition. For guidance on how to do this and what is required, please refer to the following document: '*The Building Regulations 2010 – Sanitation, hot water safety and water efficiency*', Appendix A (p36-44).

https://assets.publishing.service.gov.uk/government/uploads/system/uploads/attachment_data/file/504207/BR_PDF_AD_G_2015_with_2016_amendments.pdf

Details Submitted for Approval:

Water Efficiency Calculator
Application Form

Decision: The details submitted in relation to this condition are approved

Reason for Decision:

The water efficiency calculator submitted confirms that the total water consumption of 90.84ltrs per person per day will be achieved. As this is below the 110ltrs per person per day requirement for water consumption, the condition can be discharged.

Please note that in accordance with national planning guidance, discharge of condition applications are procedural in nature and do not require public consultation. While third-party representations may occasionally be received, they are not formally invited and do not form part of the statutory decision-making process. The assessment of this application has been based solely on whether the submitted details satisfy the requirements of the relevant planning condition(s).

This letter acts as official confirmation and therefore I suggest that you attach it to the decision notice as evidence that you have complied with the requirements of the relevant condition(s).

Yours faithfully

Head of Development Management

NOTES:

1. **Approved Conditions:**

If the condition(s) have been discharged, you may proceed with the development in accordance with the approved details. Please ensure that the approved documents or plans are implemented on-site and adhered to as part of the development. It is important to comply with all conditions of the planning permission to ensure the development remains lawful.

2. **Refused Conditions:**

If the discharge of the condition(s) has been refused, you may submit revised details or further information to address the issues raised as part of a further discharge of the condition's application. Please ensure that any resubmission adequately addresses the reasons for refusal. Alternatively, you can appeal the Council's decision (see below for details).

3. **Partially Discharged Conditions:**

If the condition(s) have been partially discharged, the remaining details that are required must be submitted for further consideration. You should provide the necessary documents in accordance with any timeframe or trigger specified in the condition to allow for the full discharge of the condition(s).

Right of Appeal:

If you are aggrieved by the decision to refuse to discharge a condition or if the condition has only been partially discharged, you have the right to **appeal** the decision to the **Planning Inspectorate**.

The appeal must be made within **6 months** from the date of this decision notice. If the appeal is submitted after this 6 month period, the Planning Inspectorate will only consider it if there are exceptional circumstances.

The procedure for making an appeal is set out under **Section 78 of the Town and Country Planning Act 1990** (as amended), along with the relevant provisions in the **Planning and Compulsory Purchase Act 2004**.

For detailed guidance on how to submit your appeal, please visit the Planning Inspectorate's website:

<https://www.gov.uk/appeal-planning-decision>

Please be aware that the appeal process will focus on whether the submitted details meet the requirements set out in the original planning condition(s) and relevant planning policies.