

To:	Alex Edge	From:	Rahul Dixit
------------	-----------	--------------	-------------

Planning App Ref:	PL/2026/00829
Service Ref:	Drainage
Date:	20/05/2026

PROPOSAL

Full planning permission for erection of two of self-build dwellings with garages and associated access, landscaping and other works.

SITE LOCATION

5 Pretoria Road, Ludgershall, Andover, Wiltshire SP11 9PB.

SUMMARY OF THE CONSULTEE POSITION

Object	
Holding Objection: Further information required	
Support	
No comment	
No objection	
No objection subject to conditions	X
Consultation not required	

APPLICATION DOCUMENTS REVIEWED

- Existing and Proposed Site Block Plan
- Location Plan
- Proposed Elevations and Floor Plans

ASSESSMENT OF THE PROPOSAL

Context

In planning terms, flood risk refers to the potential for development to increase the likelihood or severity of flooding on-site or elsewhere, while drainage considerations relate to the capacity of the site and surrounding infrastructure to manage surface water runoff in a sustainable and effective manner.

The local planning authority must be satisfied that the proposed development will not increase flood risk, either on-site or elsewhere, and that surface water will be managed in a sustainable and coordinated manner.

Where necessary, planning conditions or legal agreements may be used to secure the implementation, maintenance, and monitoring of SuDS and other drainage infrastructure.

Assessment

The SFRA identifies the site as being within Flood Zone 1 with a low risk of fluvial and pluvial flooding and a high risk of groundwater flooding, with groundwater levels measured between 0.025 m and 0.5 m beneath the ground surface.

The applicant seeks planning permission for the erection of two self-build dwellings with garages and associated access, landscaping, and other works.

No drainage details are provided within the current application.

RECOMMENDATION

No objection subject to the following conditions

- 1. No development shall take place until a surface water drainage strategy, complying with Wiltshire Council requirements, NPPF, PPG and the National Standards for SuDS has been submitted to and approved in writing by the Local Planning Authority.**

In order to discharge the above drainage condition the following additional information must be provided:

- A detailed surface water drainage strategy is required to support the application and shall be prepared in accordance with the [surface water disposal hierarchy](#) and other requirements from [National Standards for SuDS](#). The applicant is referred to the informatives for details of what information is required from a drainage/flood risk perspective.
- The site is located in an area susceptible to groundwater flooding. Therefore, in line with [Wiltshire Council's Groundwater Management Strategy](#), the applicant is required to carry out a site-specific groundwater flood risk assessment that includes all available information and data from local sources such as historical records, parish councils, flood action groups and borehole records. In areas susceptible to groundwater flooding infiltration SuDS is not permitted unless it can be demonstrated to be appropriate. The groundwater assessment must include/consider the following:
 - Groundwater level monitoring (taking into account seasonal variations).
 - The interaction between different sources of flooding.
 - How groundwater will impact on the proposed drainage system.
 - The interaction between groundwater, groundwater recharge and aquifers.

The applicant is referred to Wiltshire Council's [Surface Water Soakaway Guidance](#) for the standards that must be met for planning approval and adoption.

INFORMATIVES

- All new drainage will need to comply fully with Building Regulations Part H (and they should engage with the building control department in order to ensure this).
- In line with the NPPF and National Standards for SuDS, the applicant should seek to use SuDS wherever practicable as part of the surface water drainage strategy.
- Any new connections to sewers will be subject to S106 agreement under the Water Industry Act with the Sewerage Undertaker.
- Prior to any works commencing on the upstream drainage network, the approved outfall structure and flow control device shall be fully constructed, tested, and commissioned. No discharge to the receiving system (including watercourses, waterbodies, sewers, or drains) shall occur until these measures are operational to ensure compliance with agreed discharge rates and prevent an increase in flood risk elsewhere.

The developer should provide the following information as part of future planning applications in accordance with Wiltshire Council requirements, NPPF, PPG and Non Statutory Technical Standards for SuDS:

- Evidence that the [surface water disposal hierarchy](#) has been applied.
- The strategy mimics the existing drainage characteristics of the site by retaining and utilising any existing drainage features.
- Soakaway testing in accordance with BRE365, and groundwater level monitoring (taking into account seasonal variations).
- If infiltration is proposed, it is implemented in manner that does not create an offsite impact, particularly if there are reports of groundwater flooding in the area.
- Existing pre and post development runoff rates for the site, in accordance with Wiltshire Council's betterment policy update, which can be found [here](#).
- Calculations that demonstrate the sizing of any attenuation/ SuDS features and cross section drawings of these features.
- Pre and post development exceedance routing that demonstrates flood risk is not increased elsewhere.
- Evidence that the finished floor levels are above the maximum predicted 100-year flood level or if no flooding is predicted, at a sufficient height above the SW drainage cover levels.
- Evidence that the proposed drainage design provides a sufficient level of water treatment.
- Consent for any outfalls from the proposed drainage systems into a public sewer or other drainage system not owned by the applicant.
- Details of how the proposed and existing drainage features on the site will be maintained and managed after completion with confirmation from the relevant authority that they will adopt any systems that are being offered for adoption.

RELEVANT PLANNING POLICY & GUIDANCE

National Planning Policy Framework (NPPF) [NPPF December 2024 Link](#)
Planning and Flood Risk (Paras 170–182)

Wiltshire Core Strategy – Adopted January 2015 [Wiltshire Core Strategy Link](#)
Core Policy 67 requires that all new development must address flood risk from all sources and not increase flood risk elsewhere. It supports the use of Sustainable Drainage Systems (SuDS) and requires that developments demonstrate how surface water will be managed sustainably.

Wiltshire Local Plan (emerging) [Local Plan Review Link](#)

Development must avoid high flood risk areas using the sequential approach. Proposals require a Flood Risk Assessment, Surface Water Drainage Strategy, and Groundwater Assessment where relevant. All schemes must include Sustainable Drainage Systems (SuDS), with major developments achieving a 30% reduction in runoff compared to greenfield rates, following the surface water discharge hierarchy.

Culverting and building over watercourses is discouraged, and natural drainage features should be retained or restored. Drainage strategies must ensure safety during extreme flood events (1-in-100-year + climate change) and provide safe access/egress. SuDS should also deliver biodiversity, amenity, and water quality benefits.

Supplementary Planning Documents

Wiltshire Council Drainage Betterment Strategy (2024) [SPD Link](#)

This technical guidance outlines expectations for surface water discharge hierarchy, attenuation, exceedance routes, water quality, and post-development monitoring.

Wiltshire Design Guide (March 2024) [SPD Link](#)

Includes principles of good design, including integration of SuDS and flood resilience.

Other Relevant Policies and Guidance

Planning Practice Guidance (PPG) – Flood Risk and Drainage [Guidance Link](#)

Covers detailed expectations for flood risk assessments, SuDS design, discharge hierarchy, sequential testing and climate change allowances.

Wiltshire SFRA (2024) [SFRA Link](#)

This document underpins the Sequential and Exception Test application and provides site screening evidence.

Section 19 Flood Investigation Reports [Section 19 Reports Link](#)

These documents summarise investigations into significant local flood incidents and establish what caused the flooding, how authorities responded, and actions needed to prevent future floods.

National Standards for Sustainable Drainage Systems (SuDS) June 2025 [Guidance Link](#)

Establishes mandatory criteria for runoff destination hierarchy, interception, flood resilience, water quality, amenity, biodiversity, and long-term maintenance for all new developments in England.

SuDS Manual (CIRIA C753)

This document set outs design principles, especially where attenuation, exceedance routing, and water quality are discussed.

Infiltration drainage design must be supported by ground investigations, including infiltration testing in accordance with *British Research Establishment (BRE) Digest 365 – Soakaway Design*, and groundwater level monitoring that accounts for seasonal variation.