

To:	Kate Clements	From:	Drainage Team (Arun Govind T)
------------	---------------	--------------	-------------------------------

Planning App Ref:	PL/2026/02541
Service Ref:	Drainage
Date:	12/06/2026

PROPOSAL

Householder planning permission
Single Storey Side and Rear Extension

SITE LOCATION

Sandyrood, Giles Lane, Landford, Salisbury, SP5 2BG

SUMMARY OF THE CONSULTEE POSITION

Object	
Holding Objection: Further information required	X
Support	
No comment	
No objection	
No objection subject to conditions	
Consultation not required	

APPLICATION DOCUMENTS REVIEWED

- Application Form
- Flood Risk Assessment
- Location and Proposed Block Plan
- Proposed Ground Floor Plan

ASSESSMENT OF THE PROPOSAL

Context

In planning terms, flood risk refers to the potential for development to increase the likelihood or severity of flooding on-site or elsewhere, while drainage considerations relate to the capacity of the site and surrounding infrastructure to manage surface water runoff in a sustainable and effective manner.

The local planning authority must be satisfied that the proposed development will not increase flood risk, either on-site or elsewhere, and that surface water will be managed in a sustainable and coordinated manner.

Where necessary, planning conditions or legal agreements may be used to secure the implementation, maintenance, and monitoring of SuDS and other drainage infrastructure.

Assessment

The application has been supported with a Site-Specific Flood Risk Assessment (FRA). It should be noted that our comments below are reliant on the accuracy and completeness of the FRA and we do not take any responsibility for incorrect data or interpretation made by the authors.

The proposal is a single storey domestic extension to an existing dwelling replacing an existing garage/covered area. The applicant states that there is a negligible resultant increase in impermeable area.

The majority of the site, including the existing dwelling and proposed extension, is situated within Flood Zone 1. The western boundary of the site transitions into Flood Zones 2 and 3, due to the proximity of an adjacent watercourse.

The finished floor level of the existing house, which will be maintained for the new extension, is significantly higher than the typical water level of the adjacent watercourse. Flood-resilient measures including waterproof membranes and raised electrical circuitry are also proposed.

Any surface water runoff arising from the extension is proposed to be controlled using permeable paving and/or a soakaway system, positioned no less than 5 metres away from the building. No infiltration testing results or existing drainage arrangements have been provided to confirm the feasibility of the proposed drainage strategy.

The Wiltshire Council Strategic Flood Risk Assessment, [SFRA Data Explorer](#), indicates that the site has a high level of risk from ground water flooding with groundwater levels either at or very near (within 0.025m of) the ground surface.

RECOMMENDATION

Holding objection as further information required

At this stage, a full assessment cannot be completed due to insufficient information. The following documents/information are required to enable a proper review of the drainage and flood risk aspects of the proposal:

- Evidence that soakage tests have been undertaken in accordance with BRE 365 to demonstrate that infiltration is feasible by the provision of calculations that demonstrate that the soakaway has been designed for:
 - 1 in 10yr + cc flows (for individual properties)
 - Half drain time <24hrs
 - Appropriate factor of safety in line with CIRIA C753 (Table 25.2) guidance has been included.
- Evidence that the highest groundwater level (taking into account seasonal variations) has been determined and this is at least 1m below the proposed bottom of any soakaway.
- Drainage layout plan indicating arrangement of drainage features and permeable paving and/or soakaway.

Following the removal of the holding objection, the drainage team have the following conditions which need to be addressed by the applicant

- Cross section drawings of proposed permeable paving and/or soakaway.

INFORMATIVES

- The EA's standing advice for minor extensions will apply.
- All new drainage will need to comply fully with Building Regulations Part H (and they should engage with the building control department in order to ensure this).
- In line with the NPPF and National Standards for SuDS, the applicant should seek to use SuDS wherever practicable as part of the surface water drainage strategy.
- There must be no interruption to the existing surface water and/or land drainage arrangements of the surrounding land as a result of the operations on the site. Provisions must be made to ensure that all existing drainage systems continue to operate effectively.

RELEVANT PLANNING POLICY & GUIDANCE

National Planning Policy Framework (NPPF) [NPPF December 2024 Link](#)
Planning and Flood Risk (Paras 170–182)

Wiltshire Core Strategy – Adopted January 2015 [Wiltshire Core Strategy Link](#)
Core Policy 67 requires that all new development must address flood risk from all sources and not increase flood risk elsewhere. It supports the use of Sustainable Drainage Systems (SuDS) and requires that developments demonstrate how surface water will be managed sustainably.

Wiltshire Local Plan (emerging) [Local Plan Review Link](#)
Development must avoid high flood risk areas using the sequential approach. Proposals require a Flood Risk Assessment, Surface Water Drainage Strategy, and Groundwater Assessment where relevant. All schemes must include Sustainable Drainage Systems (SuDS), with major developments achieving a 30% reduction in runoff compared to greenfield rates, following the surface water discharge hierarchy.

Culverting and building over watercourses is discouraged, and natural drainage features should be retained or restored. Drainage strategies must ensure safety during extreme flood events (1-in-100-year + climate change) and provide safe access/egress. SuDS should also deliver biodiversity, amenity, and water quality benefits.

Supplementary Planning Documents

Wiltshire Council Drainage Betterment Strategy (2024) [SPD Link](#)
This technical guidance outlines expectations for surface water discharge hierarchy, attenuation, exceedance routes, water quality, and post-development monitoring.

Wiltshire Design Guide (March 2024) [SPD Link](#)
Includes principles of good design, including integration of SuDS and flood resilience.

Other Relevant Policies and Guidance

Planning Practice Guidance (PPG) – Flood Risk and Drainage [Guidance Link](#)
Covers detailed expectations for flood risk assessments, SuDS design, discharge hierarchy, sequential testing and climate change allowances.

Wiltshire SFRA (2024) [SFRA Link](#)
This document underpins the Sequential and Exception Test application and provides site screening evidence.

Section 19 Flood Investigation Reports [Section 19 Reports Link](#)
These documents summarise investigations into significant local flood incidents and establish what caused the flooding, how authorities responded, and actions needed to prevent future floods.

National Standards for Sustainable Drainage Systems (SuDS) June 2025 [Guidance Link](#)

Establishes mandatory criteria for runoff destination hierarchy, interception, flood resilience, water quality, amenity, biodiversity, and long-term maintenance for all new developments in England.

SuDS Manual (CIRIA C753)

This document set out design principles, especially where attenuation, exceedance routing, and water quality are discussed.

Infiltration drainage design must be supported by ground investigations, including infiltration testing in accordance with *British Research Establishment (BRE) Digest 365 – Soakaway Design*, and groundwater level monitoring that accounts for seasonal variation.