

19:12



4 Messages

Job Ref: ERW318



Scottish & Southern
Electricity Networks

Map Centre: 385025, 158628

Grid Ref: ST85025862

Scale: 1:2500

Page Size: A4

Plot Date: 05/08/2020

Designer Name: White Adam

Job Number:

Network Type: LV

UNCONTROLLED COPY

Subject to revision

Master held by SSEN Asset Data Team - Asset.Data@sse.com

Legend

Segments [Electric]	Pole Structure Existing Location - Single
Cable Segment LV Route - 230.0 V Existing	Pole Structure Existing Location - H
Cable Segment LV Route - 400.0 V Existing	Substation Site [Electric]
Line Segment LV Route - 230.0 V Existing	Substation Existing Location
Distribution Structures [Electric]	Common [Electric]
Pillar/Link Box New Extant - Existing	Open LV Existing Route
Pillar/Link Box Existing Location - Link Box	

VOLTAGES (V)

LV (Low Voltage) and Services	up to 1,000V
HV (High Voltage)	over 1,000V to 11,000V
EHV (Extra High Voltage)	22,000V to 132,000V
Transmission	275,000V and 400,000V

NORMAL DEPTH TO THE TOP OF THE CABLE WHEN LAID

	Services	LV	HV	EHV
FOOTPATH/UNMADE	0.45m	0.45m	0.6m	0.8m
ROAD CROSSING	0.6m	0.6m	0.75m	0.9m
AGRICULTURAL	1m	1m	1m	1.1m

WARNING

There may have been subsequent alterations to the surface levels. Trial holes must be taken to determine positions and depths of cables. HS (G) 47 Booklet from the Health and Safety Executive - Avoiding Danger from Buried Cables - should be consulted before commencing excavation work.
WHEN WORKING IN THE VICINITY OF OVERHEAD LINES THE HEALTH AND SAFETY GUIDANCE NOTE G56 SHOULD BE CONSULTED (AVAILABLE FROM THE HSE WEBSITE)

If you are unsure & need to seek advice before commencing excavations please contact;

General Enquiries

0800 048 3516

BASED UPON THE ORDNANCE SURVEY DATA TO THE SATISFACTION OF THE CONTROLLER OF H.M. STATISTICAL OFFICE.
CROWN COPYRIGHT RESERVED

This supplies have been made by or with the authority of Scottish and Southern Energy Power Distribution Ltd. pursuant to section 47 of the Copyright, Designs and Patents Act 1988 (The Act). Under the Act, the Act provides a narrow exception to copyright, the copy must not be reproduced without the prior permission of the copyright owner.

Scottish and Southern Energy Power Distribution Ltd.
Registered in Scotland No. SC234888
Registered Office: Inverclyde House, 100 Westfield Road, Perth, PH1 3AG