
Ivy House

From REDACTED

Date Mon 2026-07-06 15:02

To Card, Pippa <Pippa.Card@wiltshire.gov.uk>

 1 attachment (59 KB)

Screenshot 2026-07-06 145944.png;

Hi Pippa,

To elaborate further on the drainage proposal:


We will be opening up the existing timber boxing to access the hot and cold water supplies from the visitors' WC in the corridor opposite, which will provide the water supply for the new en-suite.

In relation to the drainage, we will connect to the existing foul drainage on the west elevation by coring through the wall to form the new connection.

I have attached a screenshot to help illustrate the proposed arrangement.

Regards,



Estates department Marlborough College, Bath Road, Marlborough, Wiltshire, SN8 1PA Office: +44 (0) 1672
 marlboroughcollege.org

DISCLAIMER: "Opinions, conclusions and other information contained in this e-mail that do not relate to the official business of Marlborough College shall not be understood as endorsed or given by the College. Any attachments are confidential and may be the subject of legal privilege. Any use, copying or disclosure other than by the intended recipient is unauthorised. If you have received this message in error, please notify the sender immediately and delete this message and any copies from your computer and network"

DISCLAIMER: "Opinions, conclusions and other information contained in this e-mail that do not relate to the official business of Marlborough College shall not be understood as endorsed or given by the College. Any attachments are confidential and may be the subject of legal privilege. Any use, copying or disclosure other than by the intended recipient is unauthorised. If you have received this message in error, please notify the sender immediately and delete this message and any copies from your computer and network"

