

[REDACTED]

Subject: FW: PL/2026/03267
Attachments: 7075-SK03 REV - SuDS DETAILS.pdf

Hi,

Please can the attached (& a redacted version of the below) be added to the file & please can drainage be re-consulted (14 days).

Thanks,
Bella

From: [REDACTED]
Sent: 17 August 2026 09:37
To: [REDACTED]
Subject: Re: PL/2026/03267

Good morning Isobella,

Please find attached the additional drainage information that has been requested for the above application.

Our drainage consultant would also like to add the following;

In regards to the pipe loadings, it is standard practice to have collector and distribution pipes within the permeable paving sub base. The Surface of the permeable paving and associated sub base disperses loadings. The perforated pipe is recommended to be a solid wall pipe and not a perforated coiled pipe to provide additional rigidity and strength.

Kind regards,

James Hooper
Associate Director & Architectural Technician

Willis & Co. (Chartered Town Planners)
30 The Causeway,
Chippenham,
Wiltshire,
SN15 3DB

Tel: [REDACTED]
Website: www.willisand.co.uk

Willis & Company (Town Planning) Limited
Registered in England No. 3648401