

Application Number:	PL/2026/01623
Location:	Premier Inn, Pearce Way, Bishopdown, Salisbury, SP1 3GU
Proposal:	Extension to existing hotel to provide additional bedrooms, together with alterations to the car park and all associated works.

[SP1 3GU - Google Maps](#)

[Salisbury, England - Google Maps](#)

I refer to the Construction Management Plan (CMP) submitted in support of the application.

The content of the CMP is considered acceptable, in highway terms, having regard to the limited number of traffic movements and staff vehicles proposed.

However, the CMP does not include a plan of the proposed compound in order to identify the location and any impact it may have on the existing car parking and operation of the site.

It is therefore recommended that an amended CMP is submitted which includes a scaled drawing of the compound to identify its location and the facilities contained within it.

Amanda Hall
Highways Development Management Engineer