

Highway Development Management Consultation Response

Planning Application Ref: PL/2026/04830

Site Address: 2 Battlewell, Purton, Swindon, SN5 4BT.

Proposal: New detached garage to front garden and reformed existing front garden wall

Date of Consultation Response: 08/09/2026

I refer to the above planning application dated 13/08/2026 seeking permission for a new detached garage to front garden and reformed existing front garden wall.

The site is located to the north of Battlewell, a private road which connects to the east with Restrop Road, a C classified section of public highway subject to a speed limit of 30mph. There are no proposals to alter the existing access with the public highway. Any alterations to Battlewell will require third party permission.

The proposals seek to provide a new double garage and access alterations. The internal driveway would be widened at the frontage to provide access and turning within the curtilage. There is proposed boundary treatment at the point where the curtilage in the form of a wall and gated access. The gates are proposed to open into the site and the wall appears to be at the same height as the existing wall but has curved corners at the access which would provide some improvements to existing visibility.

The proposals to place a new garage structure within the curtilage of the property would not increase the vehicular attraction of the site and any alterations to Battlewell or the access with Battlewell will require third party permission. It is therefore considered that the proposals are acceptable in relation to highways.

The proposals would not be considered to result in any significant increased trip generation, nor alter the access in any way which would be detrimental to the operation of Battlewell and it is therefore recommended that no highway objection be raised.

If you have any queries regarding the above advice, please contact:

HighwaysDevelopment@wiltshire.gov.uk