

To:	Pippa Card	From:	Drainage Team (Arun Govind T)
------------	------------	--------------	-------------------------------

Planning App Ref:	PL/2026/05171
Service Ref:	Drainage
Date:	11/09/2026

PROPOSAL

Listed building consent (Alt/Ext)

Repairs and maintenance to the dam headwall and culverts east of the bank of 3 sluices at Wilton Water

SITE LOCATION

Wilton Water Reservoir Dam Headwall, Crofton Road, Crofton, Great Bedwyn, SN8 3DW

SUMMARY OF THE CONSULTEE POSITION

Object	
Holding Objection: Further information required	
Support	
No comment	
No objection	
No objection subject to conditions	X
Consultation not required	

APPLICATION DOCUMENTS REVIEWED

- Application Form
- Block Plan
- Design Access & Heritage Statement
- Location Plan 1-1250 Scale

ASSESSMENT OF THE PROPOSAL

Context

In planning terms, flood risk refers to the potential for development to increase the likelihood or severity of flooding on-site or elsewhere, while drainage considerations relate to the capacity of the site and surrounding infrastructure to manage surface water runoff in a sustainable and effective manner.

The local planning authority must be satisfied that the proposed development will not increase flood risk, either on-site or elsewhere, and that surface water will be managed in a sustainable and coordinated manner.

Where necessary, planning conditions or legal agreements may be used to secure the implementation, maintenance, and monitoring of SuDS and other drainage infrastructure.

Assessment

The proposal comprises repairs to the dam wall, concrete slab and culvert joints, including masonry reinstatement and cementitious grouting, to prevent leakage and address settlement-related defects, and should not result in a significant increase in impermeable area or associated surface water runoff.

However, the submitted documents do not provide sufficient information on the management of water during construction. The design statement acknowledges that the full extent of some repairs will not be understood until the area around the dam wall has been dewatered. The proposals could therefore temporarily affect reservoir flows, culvert capacity and downstream drainage arrangements.

RECOMMENDATION

No objection subject to the following conditions

1. **No development shall commence on site until a construction management plan, which shall include monitoring of, and measures to retain, the existing vegetation across the site, together with details of drainage arrangements during the construction phase, has been submitted to and approved in writing by the Local Planning Authority in consultation with the Lead Local Flood Authority.**

In order to discharge the above drainage condition the following additional information must be provided:

- A Construction Management Plan should be submitted that includes details of:
 - Sequence of dewatering, flow diversion, culvert and headwall repairs, grouting and embankment reinstatement.
 - Temporary flow-diversion and dewatering arrangements.
 - Location, rate and treatment of temporary discharges.
 - Measures to maintain culvert, sluice and downstream flow capacity during each phase.
 - Measures to prevent sediment, grout and pollutants entering the watercourse.
 - Emergency procedures for high-water conditions or temporary works failure.

INFORMATIVES

- An environmental permit is required for any works within 8m of a main river. Consult the [Environment Agency's main river map](#) to see if a river/watercourse is designated as a main river. For more guidance on environmental permits, consult the [website](#).

The Environment Agency issues environmental permits, however, as Wiltshire Council is the Lead Local Flood Authority that has the lead responsibility for surface water management, **the discharge rate from the site must be agreed with Wiltshire Council** as part of agreeing the surface water drainage strategy for the site.

RELEVANT PLANNING POLICY & GUIDANCE

National Planning Policy Framework (NPPF) [NPPF December 2024 Link](#)
Planning and Flood Risk (Paras 170–182)

Wiltshire Core Strategy – Adopted January 2015 [Wiltshire Core Strategy Link](#)
Core Policy 67 requires that all new development must address flood risk from all sources and not increase flood risk elsewhere. It supports the use of Sustainable Drainage Systems (SuDS) and requires that developments demonstrate how surface water will be managed sustainably.

Wiltshire Local Plan (emerging) [Local Plan Review Link](#)
Development must avoid high flood risk areas using the sequential approach. Proposals require a Flood Risk Assessment, Surface Water Drainage Strategy, and Groundwater Assessment where relevant. All schemes must include Sustainable Drainage Systems (SuDS), with major developments achieving a 30% reduction in runoff compared to greenfield rates, following the surface water discharge hierarchy.

Culverting and building over watercourses is discouraged, and natural drainage features should be retained or restored. Drainage strategies must ensure safety during extreme flood events (1-in-100-year + climate change) and provide safe access/egress. SuDS should also deliver biodiversity, amenity, and water quality benefits.

Supplementary Planning Documents

Wiltshire Council Drainage Betterment Strategy (2024) [SPD Link](#)
This technical guidance outlines expectations for surface water discharge hierarchy, attenuation, exceedance routes, water quality, and post-development monitoring.

Wiltshire Design Guide (March 2024) [SPD Link](#)
Includes principles of good design, including integration of SuDS and flood resilience.

Other Relevant Policies and Guidance

Planning Practice Guidance (PPG) – Flood Risk and Drainage [Guidance Link](#)
Covers detailed expectations for flood risk assessments, SuDS design, discharge hierarchy, sequential testing and climate change allowances.

Wiltshire SFRA (2024) [SFRA Link](#)
This document underpins the Sequential and Exception Test application and provides site screening evidence.

Section 19 Flood Investigation Reports [Section 19 Reports Link](#)
These documents summarise investigations into significant local flood incidents and establish what caused the flooding, how authorities responded, and actions needed to prevent future floods.

National Standards for Sustainable Drainage Systems (SuDS) June 2025 [Guidance Link](#)

Establishes mandatory criteria for runoff destination hierarchy, interception, flood resilience, water quality, amenity, biodiversity, and long-term maintenance for all new developments in England.

SuDS Manual (CIRIA C753)

This document set outs design principles, especially where attenuation, exceedance routing, and water quality are discussed.

Infiltration drainage design must be supported by ground investigations, including infiltration testing in accordance with *British Research Establishment (BRE) Digest 365 – Soakaway Design*, and groundwater level monitoring that accounts for seasonal variation.