

The Planning (Listed Building and Conservation Areas) Act 1990

Listed building consent - Approve with Conditions

Application Reference Number: PL/2026/01244

Decision Date: 02/10/2026

Applicant:	Clare Vines 43 - 45 London Road, Chippenham, Wiltshire, SN15 3AJ
Particulars of Development:	Replacement of three windows - Front elevation, 1st Floor LHS; RHS Gable & Rear elevation, 1st floor RHS.
At:	43 - 45 London Road, Chippenham, SN15 3AJ

In pursuance of its powers under the above Act, the Council hereby GRANT LISTED BUILDING CONSENT for the above development to be carried out in accordance with the application and plans submitted (listed below), subject to compliance with the condition(s) specified hereunder:-

- 1 The works for which Listed Building Consent is hereby granted shall be begun before the expiration of three years from the date of this consent.

REASON: To comply with the provisions of Section 18 of the Planning (Listed Buildings and Conservation Areas) Act 1990 as amended by the Planning and Compulsory Purchase Act 2004.

- 2 No works shall commence to replace Window 9 until details of all new external window or metal framed glazing have been submitted to and approved in writing by the Local Planning Authority. The submitted details shall include depth of reveal, details of heads & sills at a scale of not less than 1:10 and horizontal/vertical frame sections (including sections through glazing bars) at not less than 1:2. The works shall be carried out in accordance with the approved details.

REASON: The application contained insufficient information to enable this matter to be considered prior to granting listed building consent and the matter is required to be agreed with the Local Planning Authority before development commences in order that the development is undertaken in an acceptable manner, in the interests of preserving the character and appearance of the listed building and its setting.

- 3 No works shall commence on Window 14 & 15 until details of all new external window have been submitted to and approved in writing by the Local Planning Authority. The submitted details shall include depth of reveal, details of heads, sills at a scale of not less than 1:10 and horizontal/vertical frame sections (including

sections through glazing bars) at not less than 1:2. The works shall be carried out in accordance with the approved details. The windows should have external putty and integrated glazing bars. Windows can have 12mm double glazed units.

REASON: The application contained insufficient information to enable this matter to be considered prior to granting listed building consent and the matter is required to be agreed with the Local Planning Authority before development commences in order that the development is undertaken in an acceptable manner, in the interests of preserving the character and appearance of the listed building and its setting.

Nic Thomas - Director of Planning, Economy and Climate

NOTES

1. **Other Necessary Consents.** This document only conveys permission for the proposed development under the Town and Country Planning (Listed Buildings and Conservation Areas) Act 1990 and the applicant must also comply with all the byelaws, regulations and statutory provisions in force in the area and secure such other approvals and permissions as may be necessary under the Town and Country Planning Act 1990 or other legislation.

In particular the applicant is reminded of the following matters:-

- 1.1 the need in appropriate cases to obtain approval under Building Regulations. **(The Building Regulations may be applicable to this proposal. Please contact the Council's Building Control team before considering work on site);**
 - 1.2 the need to obtain an appropriate order if the proposal involves the stopping up or diversion of a public right of way or other highway (including highway verge)
 - 1.3 the need to obtain a separate planning permission;
 - 1.4 the need to make any appropriate arrangements under the Highways Act 1980, in respect of any works within the limits of a highway. The address of the Highway Authority is County Hall, Trowbridge, BA14 8JD (It is the responsibility of the applicant to ascertain whether the proposed development affects any listed building or public right of way / other highway, including highway verge).
2. **Appeals.** If the applicant is aggrieved by the decision of the local planning authority to grant permission subject to conditions, he may appeal to the Secretary of State for the Environment in accordance with Section 20 of the Town and Country Planning (Listed Buildings and Conservation Areas) Act 1990 within six months of the date of this decision. (Information and forms relating to the appeals process can be found at the Planning Portal – www.planningportal.gov.uk/planning/appeals).