

NOTES:

Floodlighting Equipment

6 x 13m Masts (M1-M6)
Each carrying the following Floodlights :-
M1-M6
...2 x Siteco FL11-3 Blade-PL33T
M1-M6
Back Shields

Lamps = Siteco LED - 5,000K CRI 70

Illuminance Levels

Initial -
(100hrs) E.i.ave = 235Lux
Maintained -
(4000hrs) E.i.ave = 212Lux
Uniformity
Emin/Eave = 0.61
Emin/Emax = 0.28

Grid values in Lux(initial).
Grid interval = 5m.
Contour values in Lux (initial).
Contours: 5, 15, 25, 50 Lux.

Maintenance Factor = 0,90
(Based on a cleaning interval of 2 years)



www.halliday-lighting.co.uk
THIS DRAWING & THE INFORMATION CONTAINED THEREIN IS THE PROPERTY OF
HALLIDAY LIGHTING LTD AND SHOULD NOT BE COPIED IN WHOLE OR IN PART,
DISCLOSED TO ANY THIRD PARTY OR USED FOR ANY OTHER PURPOSE WITHOUT
THE PRIOR WRITTEN CONSENT OF HALLIDAY LIGHTING
email - info@halliday-lighting.co.uk

PROJECT NAME:
Corsham RFC

DRAWING TITLE:
Proposed Floodlighting

DRAWN BY: HJ	DATE: 09/06/2026
CHECKED BY: JDW	SCALE: NTS
DRAWING No: HLS12288	REVISION: REV2

2	09/06/26	Reduced Spill	HJ	JDW
1	30/04/26	Moved Masts	IH	HJ
0	30/04/26	ORIGINAL ISSUE	IH	HJ